

06 October 2020

Our Ref: 502436/20.23/MB/mvw

TO ALL TENDERERS

Dear Sir / Madam

TDR64/2020/2021: CONSTRUCTION OF CIVIL ENGINEERING SERVICES FOR 680 ERVEN AND TEMPORARY RELOCATION AREA (TRA): PHASE 1

ADDENDUM TO TENDER DOCUMENT NO. 2

This "Addendum to Tender Documents" is an addition to the Tender Documents listed in the Schedule of Documents. Any tender submitted will be deemed to be in accordance with these Documents amended in accordance with the following instructions:

ATD 2-1 Part T2: RETURNABLE DOCUMENTS: Local Content Declaration

ATD 2-1.1 Delete Part T2: Returnable Documents T2–Pages 56, 65 and 72 and replace with the attached Part T2: Returnable Documents T2– Pages 56, 65 and 72.

ATD 2-2 Part C2.2: BILL OF QUANTITIES:

ATD 2-2.1 Emfuleni (Phase 1 and 2): Section B: Sewerage Reticulation: Item B11.5: Delete 'Rate only' in the 'Amount' column. Quantity to read 1 193m.

ATD 2-2.2 ASLA C: Section B: Sewerage Reticulation: Delete C2-Page 75 and replace with the attached BOQ_ASLA C_C2-Page 75.

ATD 2-2.4 ASLA E: Section B: Sewerage Reticulation: Item B11.5: Delete 'Rate only' in the 'Amount' column. Quantity to read 30m.

ATD 2-2.5 ASLA E: Section B: Sewerage Reticulation: Item B11.6: Delete 'Rate only' in the 'Amount' column. Quantity to read 6m³.

ATD 2-3 Part C3: SCOPE OF WORK:

ATD 2-3.1 PSLC: Cable Ducts on C3–Page 97, Item PSLC 3 Materials, PSLC 3.1 Ducts, amend the Clause to read: *"Ducts for Telkom cables and electricity cables shall be PVC-U Class 51 sewer pipes that comply with SANS 791 or HDPE ducts of Class PE 100 PN6.3. The Telkom ducts shall be pigmented green".*

ATD 2-4 Part C5: TENDER DRAWINGS:

ATD 2-4.1 The following revised drawings are issued for tendering purposes with this Addendum:

502436-0000-DRG-CC-0001: Sewer Details (1 of 2)

502436-0000-DRG-CC-0007: Retaining wall details

502436-0000-DRG-CC-0008: Ablution Facility Details

502436-0000-DRG-CC-0009: Sewer and Water House Connection Details (1 of 2)

502436-0000-DRG-CC-0010: Sewer and Water House Connection Details (2 of 2)

NB!! Please confirm receipt of this addendum on the attached Acknowledgement Form and fax a signed copy thereof to us. If the Acknowledgement Form is not signed and returned to us your tender may be declared non-responsive.

Yours faithfully



M BOTHA Pr Tech Eng

Associate

pp Zutari

Encl. *Annexure A – Acknowledgement Form*

Part T2: Returnable Documents T2–Pages 56, 65 and 72

BOQ_AS LA C_C2-Page 75

Drawing 502436-0000-DRG-CC-0001

Drawing 502436-0000-DRG-CC-0007

Drawing 502436-0000-DRG-CC-0008

Drawing 502436-0000-DRG-CC-0009

Drawing 502436-0000-DRG-CC-0010

ACKNOWLEDGEMENT FORM

502436

TO : Zutari (Pty) Ltd

Fax No : (044) 873 5843

E-mail : marilise.vanwyk@zutari.com
marius.botha@zutari.com

Attention : Marius Botha

TENDER NO. TDR64/2020/2021

**CONSTRUCTION OF CIVIL ENGINEERING SERVICES FOR 680 ERVEN AND
TEMPORARY RELOCATION AREA (TRA): PHASE 1**

ADDENDUM TO TENDER DOCUMENTS NO. 2

**We acknowledge receipt of the above Addendum and confirm that any
tender we submit will take account of the instructions detailed therein.**

Date

Signed :

on behalf of

(PLEASE PRINT)
