



ENERGY DIRECTORATE

TYPE TESTED INVERTERS/EQUIPMENT IN TERMS OF NRS 097-2-1

9 September 2024

Make	Model	Inverter / Equipment type	Test House	Certificate date	Certificate valid until	Report number	Certificate Compliance number	NRS 097-2-1			Comments
								2017 Ed. 2	2017 Ed. 2.1	2024 Ed. 3	
ABB	CM-UF0.M31	Network & system relay	TÜV SÜD	2022/10/28		713200958-000	ESY 0442540043 Rev.00	No	No		Network and system grid protection voltage and frequency relay only in accordance with VDE-AR-N 4105:2018. Must be programmed to NRS 097-2-1 or the applicable South African Grid Codes and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list.
ABB	CM-UF0.M31M	Network & system relay	TÜV SÜD	2022/10/28		713200958-000	ESY 0442540043 Rev.00	No	No		Network and system grid protection voltage and frequency relay only in accordance with VDE-AR-N 4105:2018. Must be programmed to NRS 097-2-1 or the applicable South African Grid Codes and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list.
ABB	PVS - 50 - TL	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	PVS - 50 - TL - S	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	PVS - 50 - TL - SX	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	PVS - 50 - TL - SX2	Grid-tied PV inverter	TUV Rheinland	2020/01/22		28111830 029	AK 60146346 0001	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	PVS-100-TL	Grid-tied PV inverter	TUV Rheinland	2019/11/29		28110923 035	AK 60144898 0001	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
ABB	REACT2-UNO-3.6-TL	Grid-tied PV inverter	TUV Rheinland	2018/11/07		28111587 003	AK 60134062 0001	Yes			A maximum of three REACT2 -BATT may be used in combination with this inverter unit.
ABB	REACT2-UNO-5.0-TL	Grid-tied PV inverter	TUV Rheinland	2018/11/07		28111587 003	AK 60134062 0001	Yes			A maximum of three REACT2 -BATT may be used in combination with this inverter unit.
ABB	TRIO-TM-50.0-400	Grid-tied PV inverter	TUV Rheinland	2019/07/15		28110633 031	AK 60141064 0001	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Afore	AF10K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF10K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF12K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF12K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF15K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF17K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF20K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF25K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF3 6K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF30K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF3K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF3K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF3K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF4 6K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF4K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF4K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF4K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF5 5K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF5K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF5K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF5K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF6K-SL	Hybrid PV inverter grid-tied	Dekra	2021/03/10		6098057.50	6098057.01AOC		Yes		
Afore	AF6K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF6K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF8K-TH	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	AF8K-THP	Hybrid PV inverter grid-tied	Intertek	2023/05/25		230500127SHA-001	CN-PV-230262		Yes		
Afore	HNS3000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS3000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Afore	HNS3600HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS3600HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Afore	HNS4000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS4000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Afore	HNS4600HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS4600HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Afore	HNS5000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS5000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Afore	HNS5500HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS5500HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Afore	HNS6000HS	Hybrid PV inverter grid-tied	Dekra	2020/09/17		6076139.50	6076139.01AOC		Yes		
Afore	HNS6000HS-HV	Hybrid PV inverter grid-tied	Dekra	2020/09/18		6076141.50	6076141.01AOC V1.1		Yes		
Alpha	SMILE5-INV	Hybrid PV inverter grid-tied	Bureau Veritas	2019/03/22		ABYD-19JA1440FCSH	U19-0178	Yes			
Alpha	SMILE-G3-S5	Hybrid PV inverter grid-tied	Dongguan Balun	2022/08/17		BL-DG2260930-B01	BL-DG2260930D01		Yes		
Alpha	SMILE-G3-S8	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/30		BL-DG23960032-201	COCPPV08098/23E-01		Yes		
Alpha	Storion-SMILE-B3	Battery based inverter grid-tied	Bureau Veritas	2020/09/19		ABYD-ESH-P20071636	U20-0680	Yes			
AlpSolar	RG20081P01	Hybrid PV inverter grid-tied	Intertek	2024/04/09		2309A1361SHA-001	CN-PVES-240125		Yes		
AlpSolar	RG2010K1P01	Hybrid PV inverter grid-tied	Intertek	2024/04/09		2309A1361SHA-001	CN-PVES-240125		Yes		
AlpSolar	RG2012K1P01	Hybrid PV inverter grid-tied	Intertek	2024/04/09		2309A1361SHA-001	CN-PVES-240125		Yes		
Aotai	AEP- 3K548P	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/14		CN23383 001	AK 50597657 0001		Yes		
Aotai	AEP- 3K548P	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/10		CN23383 001	AK 50597657 0001		Yes		
Aotai	AEP- 4K548P	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/11		CN23383 001	AK 50597657 0001		Yes		
Aotai	AEP- 4K548P	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/12		CN23383 001	AK 50597657 0001		Yes		
Aotai	AEP- 6K548P	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/13		CN23383 001	AK 50597657 0001		Yes		
Apex	FG-H2-00 H20P100	Solar water geyser switch	Test Africa	2023/10/11	2026/10/06	WCT 23/0848	NRCS RCC 2310107	N/A	N/A		Solar geyser switch system only
Ario MetaPower	SI-38-118	Grid-tied PV inverter	SGS	2024/03/26	2029/03/26	2221 / 0162-2	2621/0162-2-CER		Yes		
Ario MetaPower	SI-40-125	Grid-tied PV inverter	SGS	2024/03/26	2029/03/26	2221 / 0162-2	2621/0162-2-CER		Yes		
Ario MetaPower	SI-48-150	Grid-tied PV inverter	SGS	2024/03/26	2029/03/26	2221 / 0162-2	2621/0162-2-CER		Yes		
Ario MetaPower	SI-55-171	Grid-tied PV inverter	SGS	2024/03/26	2029/03/26	2221 / 0162-2	2621/0162-2-CER		Yes		
Ario MetaPower	SI-69-215	Grid-tied PV inverter	SGS	2024/03/26	2029/03/26	2221 / 0162-2	2621/0162-2-CER		Yes		

Aless	HPS 30	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B01	BL-DG2080269D01	Yes			The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Aless	HPS 50	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B01	BL-DG2080269D01	Yes			The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Aless	HPS100	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B02	BL-DG2080269D02	Yes			The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Aless	HPS120	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B02	BL-DG2080269D02	Yes			The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Aless	HPS150	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/10/09		BL-DG2080269-B02	BL-DG2080269D02	Yes			The maximum DC voltage is depended on PV array and may not exceed 820 V as declared by the inverter manufacturer.
Aless	PCS100	Battery based inverter grid-tied	Dongguan Balun	2023/08/11		BL-DG2150442-B01 (G1)	BL-DG2150442D02		Yes		Models PCS 100 and PCS 250 have built-in isolation transformers.
Aless	PCS250	Battery based inverter grid-tied	Dongguan Balun	2023/08/11		BL-DG2150442-B01 (G1)	BL-DG2150442D02		Yes		Models PCS 100 and PCS 250 have built-in isolation transformers.
Aless	PCS500	Battery based inverter grid-tied	Dongguan Balun	2023/08/11		BL-DG2150442-B01 (G1)	BL-DG2150442D02		Yes		Models PCS 500 and PCS 630 must have external isolation transformers in final installation.
Aless	PCS630	Battery based inverter grid-tied	Dongguan Balun	2023/08/11		BL-DG2150442-B01 (G1)	BL-DG2150442D02		Yes		Models PCS 500 and PCS 630 must have external isolation transformers in final installation.
Blue Mountain Energy	BME-3P-WP-12 TWIN	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/20		23110JHA009-EG-ZA-002	23110JHA009-EG-ZA-C002		Yes		
Blue Mountain Energy	BME-3P-WP-15 TWIN	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/20		23110JHA009-EG-ZA-002	23110JHA009-EG-ZA-C002		Yes		
Bluesun	BMP5100	Hybrid PV inverter grid-tied	TUV NORD	2023/08/29		BL-DG2380718-201	COCPPV06004/23B-01		Yes		
Bluesun	BMP5150	Hybrid PV inverter grid-tied	TUV NORD	2023/08/29		BL-DG2380718-201	COCPPV06004/23B-01		Yes		
Bluesun	BMP5250	Hybrid PV inverter grid-tied	TUV Rheinland Group	2023/09/18		CN229F6J 004	AK 50599810 0001		Yes		
Bluesun	BMP530	Hybrid PV inverter grid-tied	TUV NORD	2023/08/29		BL-DG2380718-201	COCPPV06004/23B-01		Yes		
Bluesun	BMP550	Hybrid PV inverter grid-tied	TUV NORD	2023/08/29		BL-DG2380718-201	COCPPV06004/23B-01		Yes		
Bluesun	BMP5500	Hybrid PV inverter grid-tied	TUV Rheinland Group	2023/09/18		CN229F6J 004	AK 50599810 0001		Yes		
Bluesun	BSE10KH3	Hybrid PV inverter grid-tied	TUV SUD	2023/03/24		64.290.23.30183.01	D 093536 0019 Rev.00		Yes		
Bluesun	BSE12KH3	Hybrid PV inverter grid-tied	TUV SUD	2023/03/24		64.290.23.30183.01	D 093536 0019 Rev.00		Yes		
Bluesun	BSE15KH3	Hybrid PV inverter grid-tied	TUV SUD	2023/03/24		64.290.23.30183.01	D 093536 0019 Rev.00		Yes		
Bluesun	BSE6KH3	Hybrid PV inverter grid-tied	TUV SUD	2023/03/24		64.290.23.30183.01	D 093536 0019 Rev.00		Yes		
Bluesun	BSE8KH3	Hybrid PV inverter grid-tied	TUV SUD	2023/03/24		64.290.23.30183.01	D 093536 0019 Rev.00		Yes		
Canadian Solar	CSI-100K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-80K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI 100 K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/10/21		50376758 002	AK 50483986 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI 110 K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/10/21		50376758 002	AK 50483986 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI 75 K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/10/21		50376758 002	AK 50483986 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-100KT4001A-E	Grid-tied PV inverter	TÜV SÜD	2023/10/20		704092320201-00	D 09184 0032 Rev.1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. The inverter is not equipped with integrated network and system (NS) protection and an external NS protection system shall be installed.
Canadian Solar	CSI-100KT4001B-E	Grid-tied PV inverter	TÜV SÜD	2023/10/20		704092320201-00	D 09184 0032 Rev.1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. The inverter is not equipped with integrated network and system (NS) protection and an external NS protection system shall be installed.
Canadian Solar	CSI-100K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-100K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-100K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-120KT4001A-E	Grid-tied PV inverter	TÜV SÜD	2023/10/20		704092320201-00	D 09184 0032 Rev.1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. The inverter is not equipped with integrated network and system (NS) protection and an external NS protection system shall be installed.
Canadian Solar	CSI-110KT4001B-E	Grid-tied PV inverter	TÜV SÜD	2023/10/20		704092320201-00	D 09184 0032 Rev.1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. The inverter is not equipped with integrated network and system (NS) protection and an external NS protection system shall be installed.
Canadian Solar	CSI-110K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-110K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-120KT4001A-E	Grid-tied PV inverter	TÜV SÜD	2023/10/20		704092320201-00	D 09184 0032 Rev.1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. The inverter is not equipped with integrated network and system (NS) protection and an external NS protection system shall be installed.
Canadian Solar	CSI-15K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/02/06		CN24FHBO 001	AK 50619820 0001		Yes		
Canadian Solar	CSI-17K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/02/06		CN24FHBO 001	AK 50619820 0001		Yes		
Canadian Solar	CSI-20K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/02/06		CN24FHBO 001	AK 50619820 0001		Yes		
Canadian Solar	CSI-20KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/07		50128276 002	AK 50406933 0001		Yes		
Canadian Solar	CSI-23K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/02/06		CN24FHBO 001	AK 50619820 0001		Yes		
Canadian Solar	CSI-25K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/02/06		CN24FHBO 001	AK 50619820 0001		Yes		
Canadian Solar	CSI-25K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/04/13		50344275 002	AK 50464349 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-25KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/07		50128276 002	AK 50406933 0001		Yes		
Canadian Solar	CSI-30K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/04/13		50344275 002	AK 50464349 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-30KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/07		50128276 002	AK 50406933 0001		Yes		
Canadian Solar	CSI-33K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/04/13		50344275 002	AK 50464349 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-36K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/04/13		50344275 002	AK 50464349 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-40K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/01/26		CN24921Y 001	AK 50617371 0001		Yes		
Canadian Solar	CSI-40K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2020/04/13		50344275 002	AK 50464349 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-40KTL-GI-FL	Grid-tied PV inverter	TUV Rheinland	2018/05/03		50131287 002	AK 50406675 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-50K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/01/26		CN24921Y 001	AK 50617371 0001		Yes		
Canadian Solar	CSI-50K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/08/27		CN21F7XT 0002	AK 50516584 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-50KTL-GI	Grid-tied PV inverter	TUV Rheinland	2018/05/03		50131287 002	AK 50406675 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-60K-T4001A-E	Grid-tied PV inverter	TUV Rheinland	2024/01/26		CN24921Y 001	AK 50617371 0001		Yes		
Canadian Solar	CSI-60K-T400GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/08/27		CN21F7XT 0002	AK 50516584 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-60K-T500GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/08/27		CN21F7XT 0002	AK 50516584 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-70K-T500GL03-E	Grid-tied PV inverter	TUV Rheinland	2021/08/27		CN21F7XT 0002	AK 50516584 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Canadian Solar	CSI-80K-T400GL02-E	Grid-tied PV inverter	TUV Rheinland	2021/10/29		50 376 758 007	AK 50522798 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.

CEEG	CEEG CHIEF-12.0K-11.52kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-12.0K-15.36kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-12.0K-7.68kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-5.0K-11.52kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-5.0K-15.36kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-5.0K-7.68kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-8.0K-11.52kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-8.0K-15.36kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
CEEG	CEEG CHIEF-8.0K-7.68kWh	Hybrid PV inverter grid-tied	Dekra	2024/01/22	2029/01/22	4914634.51	4914634.01COC		Yes	
Chint	CPS SCE5KTL-120/EU	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/17		CN23FCPJ 001	AK 50573707 0001		Yes	
Chint	CPS SCE6KTL-120/EU	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/17		CN23FCPJ 001	AK 50573707 0001		Yes	
Chisage ESS	Mars-10G2-LE	Hybrid PV inverter grid-tied	Bureau Veritas	2023/12/19		CMCC-ESH-P23090073	U23-1183 (Scheme: NSOP-0032-DEU-ZE-V01)		Yes	
Chisage ESS	Mars-12G2-LE	Hybrid PV inverter grid-tied	Bureau Veritas	2023/12/19		CMCC-ESH-P23090073	U23-1183 (Scheme: NSOP-0032-DEU-ZE-V01)		Yes	
Chisage ESS	Mars-14G2-LE	Hybrid PV inverter grid-tied	Bureau Veritas	2023/12/19		CMCC-ESH-P23090073	U23-1183 (Scheme: NSOP-0032-DEU-ZE-V01)		Yes	
Chisage ESS	Mars-5G2-LE	Hybrid PV inverter grid-tied	Bureau Veritas	2023/12/19		CMCC-ESH-P23090073	U23-1183 (Scheme: NSOP-0032-DEU-ZE-V01)		Yes	
Chisage ESS	Mars-6G2-LE	Hybrid PV inverter grid-tied	Bureau Veritas	2023/12/19		CMCC-ESH-P23090073	U23-1183 (Scheme: NSOP-0032-DEU-ZE-V01)		Yes	
Chisage ESS	Mars-8G2-LE	Hybrid PV inverter grid-tied	Bureau Veritas	2023/12/19		CMCC-ESH-P23090073	U23-1183 (Scheme: NSOP-0032-DEU-ZE-V01)		Yes	
Conti	CSHI-3500	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14		64.290.21.30646.04	D 115385 0001 Rev.00		Yes	
Conti	CSHI-5500X12	Hybrid PV inverter grid-tied	TUV SUD	2022/01/14		64.290.21.30646.04	D 115385 0001 Rev.00		Yes	
Deye	SUN-10K-SG02LP1-EU-AM3	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/15		CN23TB9V 001	AK 50615365 0001		Yes	
Deye	SUN-10K-SG04LP3-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2021/06/09		BL-DG2141024-B01	BL-DG2141024D01		Yes	
Deye	SUN-12K-SG01LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/05/24		CN22M50 001	AK 50544599 0001		Yes	
Deye	SUN-12K-SG02LP1-EU-AM3	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/15		CN23TB9V 001	AK 50615365 0001		Yes	
Deye	SUN-12K-SG04LP3-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2021/06/09		BL-DG2141024-B01	BL-DG2141024D01		Yes	
Deye	SUN-14K-SG01LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/05/24		CN22M50 001	AK 50544599 0001		Yes	
Deye	SUN-18K-SG01LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/05/24		CN22M50 001	AK 50544599 0001		Yes	
Deye	SUN-29.9K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13		CN23G75A 003	AK 50593991 0001		Yes	
Deye	SUN-3.6K-SG01LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-3.6K-SG01LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-3.6K-SG02LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-3.6K-SG02LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-3.6K-SG03LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2023/04/23		BL-DG2330754 B01	BL-DG2330754D01		Yes	
Deye	SUN-3.6K-SG04LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/12/13		CN22MT63 001	AK 50567952 0001		Yes	
Deye	SUN-30K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13		CN22G75A 003	AK 50593991 0001		Yes	
Deye	SUN-35K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13		CN22G75A 003	AK 50593991 0001		Yes	
Deye	SUN-3K-SG03LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2023/04/23		BL-DG2330754 B01	BL-DG2330754D01		Yes	
Deye	SUN-3K-SG04LP1-24-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/12/13		CN22MT63 001	AK 50567952 0001		Yes	
Deye	SUN-3K-SG04LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/12/13		CN22MT63 001	AK 50567952 0001		Yes	
Deye	SUN-40K-SG01HP3-EU-BM4	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13		CN22G75A 003	AK 50593991 0001		Yes	
Deye	SUN-50K-SG01HP3-EU-BM4	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13		CN22G75A 003	AK 50593991 0001		Yes	
Deye	SUN-5K-SG01LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-5K-SG01LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-5K-SG02LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-5K-SG02LP1-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/15		CN23TB9V 001	AK 50615365 0001		Yes	
Deye	SUN-5K-SG02LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-5K-SG03LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2023/04/23		BL-DG2330754 B01	BL-DG2330754D01		Yes	
Deye	SUN-5K-SG04LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/12/13		CN22MT63 001	AK 50567952 0001		Yes	
Deye	SUN-6K-SG01LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-6K-SG01LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-6K-SG02LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-6K-SG02LP1-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/15		CN23TB9V 001	AK 50615365 0001		Yes	
Deye	SUN-6K-SG02LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-6K-SG03LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2023/04/23		BL-DG2330754 B01	BL-DG2330754D01		Yes	
Deye	SUN-6K-SG04LP1-EU	Hybrid PV inverter grid-tied	TUV Rheinland	2022/12/13		CN22MT63 001	AK 50567952 0001		Yes	
Deye	SUN-7.6K-SG01LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-7.6K-SG01LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-7.6K-SG02LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-7.6K-SG02LP1-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/15		CN23TB9V 001	AK 50615365 0001		Yes	
Deye	SUN-7.6K-SG02LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-8K-SG01LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-8K-SG01LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-8K-SG02LP1-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-8K-SG02LP1-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/15		CN23TB9V 001	AK 50615365 0001		Yes	
Deye	SUN-8K-SG02LP1-EU-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/16		BL-DG21C0114-B01 (G1)	BL-DG21C0114D02		Yes	
Deye	SUN-8K-SG04LP3-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2021/06/09		BL-DG2141024-B01	BL-DG2141024D01		Yes	
Dyness	DYNE 3.0L-1P-A	Hybrid PV inverter grid-tied	TUV SUD	2023/08/29		704092366401-00	D 120387 0003 Rev.00		Yes	
Dyness	DYNE 5.0L-1P-A	Hybrid PV inverter grid-tied	TUV SUD	2023/08/29		704092366401-00	D 120387 0003 Rev.00		Yes	
Dyness	DYNE 5.0L-1P-A	Hybrid PV inverter grid-tied	TUV SUD	2023/08/29		704092366401-00	D 120387 0003 Rev.00		Yes	
Dyness	DYNE 6.0L-1P-A	Hybrid PV inverter grid-tied	TUV SUD	2023/08/29		704092366401-00	D 120387 0003 Rev.00		Yes	
Dyness	DYNE 8.0L-1P-A	Hybrid PV inverter grid-tied	TUV SUD	2023/08/29		704092366401-00	D 120387 0003 Rev.00		Yes	
Easypower	REVO8K11	Hybrid PV inverter grid-tied	TUV SUD	2023/01/17		64.290.22.31554.01	D 119631 0001 Rev. 00		Yes	
Eaton	XSTH1P036P048V01	Hybrid PV inverter grid-tied	Bureau Veritas	2019/12/10		PVZA190716C26 163818-743394	U19-0642		Yes	
Eaton	XSTH1P046P048V01	Hybrid PV inverter grid-tied	Bureau Veritas	2019/12/10		PVZA190716C26 163818-743394	U19-0642		Yes	
Eaton	XSTH1P060P048V01	Hybrid PV inverter grid-tied	Bureau Veritas	2019/12/10		PVZA190716C26 163818-743394	U19-0642		Yes	
eCactus	WH-SPHA3.6H-10.24kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA3.6H-5.12kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA4.6H-10.24kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA4.6H-5.12kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA5.0H-10.24kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA5.0H-5.12kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA6.0H-10.24kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
eCactus	WH-SPHA6.0H-5.12kWh	Hybrid PV inverter grid-tied	TUV SUD	2023/04/17		70.409.22.344.23-00	D 117109 0030 Rev.00		Yes	
EcoFlow	EFWN511	Grid-tied PV inverter	Dekra	2024/05/24		61841145.5	6184145.01COC		Yes	Grid-tied Micro-inverter
EcoFlow	EFWN511B	Grid-tied PV inverter	Dekra	2024/05/24		61841145.5	6184145.01COC		Yes	Grid-tied Micro-inverter

Page 4 of 21

Fronius	Symo GEN24 7.0 Lite hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 7.0 Plus	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 7.0 Plus hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 8.0	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 8.0 hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 8.0 Lite	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 8.0 Lite hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 8.0 Plus	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 8.0 Plus hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 9.0	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 9.0 hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 9.0 Lite	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 9.0 Lite hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	Symo GEN24 9.0 Plus	Grid-tied PV inverter	TUV Rheinland	2021/05/19		IT2157N9 001	AK 60156753 0001		Yes		
Fronius	Symo GEN24 9.0 Plus hybrid	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/29		IT2157N9 001	AK 60165075 0001		Yes		
Fronius	TAURO 50-3-D	Grid-tied PV inverter	TUV Rheinland	2022/01/27		IT221Y51 001	AK 60161577 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO 50-3-P	Grid-tied PV inverter	TUV Rheinland	2022/01/27		IT221Y51 001	AK 60161577 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO ECO 100-3-D	Grid-tied PV inverter	TUV Rheinland	2022/01/25		IT2227D0 001	AK 60161549 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO ECO 100-3-P	Grid-tied PV inverter	TUV Rheinland	2022/01/25		IT2227D0 001	AK 60161549 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO ECO 50-3-D	Grid-tied PV inverter	TUV Rheinland	2022/01/25		IT2227D0 001	AK 60161549 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO ECO 50-3-P	Grid-tied PV inverter	TUV Rheinland	2022/01/25		IT2227D0 001	AK 60161549 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO ECO 99-3-D	Grid-tied PV inverter	TUV Rheinland	2022/01/25		IT2227D0 001	AK 60161549 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Fronius	TAURO ECO 99-3-P	Grid-tied PV inverter	TUV Rheinland	2022/01/25		IT2227D0 001	AK 60161549 0001		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
GivEnergy	GIV-HY-3.6-G3-Plus	Hybrid PV inverter grid-tied	Intertek	2023/11/09		230707124GZU-001	CN-PV-230610		Yes		
GivEnergy	GIV-HY-4.6-G3-Plus	Hybrid PV inverter grid-tied	Intertek	2023/11/09		230707124GZU-001	CN-PV-230610		Yes		
GivEnergy	GIV-HY-5-G3-Plus	Hybrid PV inverter grid-tied	Intertek	2023/11/09		230707124GZU-001	CN-PV-230610		Yes		
GivEnergy	GIV-HY-6-G3-Plus	Hybrid PV inverter grid-tied	Intertek	2023/11/09		230707124GZU-001	CN-PV-230610		Yes		
Goodwe	GW 100K-HT	Grid-tied PV inverter	TUV Rheinland	2020/12/24		CN20W6U3 001	AK 50490607 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 110K-HT	Grid-tied PV inverter	TUV Rheinland	2020/12/24		CN20W6U3 001	AK 50490607 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 120K-HT	Grid-tied PV inverter	TUV Rheinland	2020/12/24		CN20W6U3 001	AK 50490607 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 12KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17		ASBJ-190C2322FTSHS	U20-O270		Yes		
Goodwe	GW 136K-HTH	Grid-tied PV inverter	TUV Rheinland	2020/12/24		CN20W6U3 001	AK 50490607 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. This 500 V a.c. inverter may only be used in plants connected to the grid via an external customer MV/LV AC transformer.
Goodwe	GW 15KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17		ASBJ-190C2322FTSHS	U20-O270		Yes		
Goodwe	GW 17KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17		ASBJ-190C2322FTSHS	U20-O270		Yes		
Goodwe	GW 17KT-DT	Grid-tied PV inverter	TUV Rheinland	2022/04/15		60395681 002	AK 50540008 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 20KN-DT	Grid-tied PV inverter	Bureau Veritas	2020/04/17		ASBJ-190C2322FTSHS	U20-O270		Yes		
Goodwe	GW 20KT-DT	Grid-tied PV inverter	TUV Rheinland	2022/04/15		60395681 002	AK 50540008 0001		Yes		
Goodwe	GW 25KT-DT	Grid-tied PV inverter	TUV Rheinland	2022/04/15		60395681 002	AK 50540008 0001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW 3000D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19		PVZA190627N029	1988AP0627N0290001		Yes		
Goodwe	GW 3600D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19		PVZA190627N029	1988AP0627N0290001		Yes		
Goodwe	GW 4200D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19		PVZA190627N029	1988AP0627N0290001		Yes		
Goodwe	GW 5000D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19		PVZA190627N029	1988AP0627N0290001		Yes		
Goodwe	GW 6000D-NS	Grid-tied PV inverter	Bureau Veritas	2020/01/19		PVZA190627N029	1988AP0627N0290001		Yes		
Goodwe	GW10K-ET	Hybrid PV inverter grid-tied	Bureau Veritas	2019/05/23		PVZA190507N014	1988AP0507N014001		Yes		
Goodwe	GW10KT-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609		Yes		
Goodwe	GW12KT-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609		Yes		
Goodwe	GW15K-ET	Grid-tied PV inverter	TUV Rheinland	2023/05/06		CN23Y4NN 001	AK 50583164 0001		Yes		
Goodwe	GW15KT-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609		Yes		
Goodwe	GW20K-ET	Grid-tied PV inverter	TUV Rheinland	2023/05/06		CN23Y4NN 001	AK 50583164 0001		Yes		
Goodwe	GW25K-ET	Grid-tied PV inverter	TUV Rheinland	2023/05/06		CN23Y4NN 001	AK 50583164 0001		Yes		
Goodwe	GW25K-MT	Grid-tied PV inverter	Bureau Veritas	2020/03/05		PVZA181008N021-R1	1888AP1008N021015		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW29.9K-ET	Grid-tied PV inverter	TUV Rheinland	2023/05/06		CN23Y4NN 001	AK 50583164 0001		Yes		
Goodwe	GW3000-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW3048-EM	Hybrid PV inverter grid-tied	TUV Rheinland	2017/07/14		50085060 001	AK 50383738 0001		Yes		
Goodwe	GW30K-ET	Grid-tied PV inverter	TUV Rheinland	2023/05/06		CN23Y4NN 001	AK 50583164 0001		Yes		
Goodwe	GW30K-MT	Grid-tied PV inverter	Bureau Veritas	2020/03/05		PVZA181008N021-R1	1888AP1008N021015		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW3600-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW3600M-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW3600S-BP	Battery based inverter grid-tied	TUV Rheinland	2018/11/12		50180648 001	AK 50419930 0001		Yes		
Goodwe	GW3600-SBP-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW3648D-ES	Hybrid PV inverter grid-tied	TUV SUD	2018/11/12		704091815302-00	D 083373 0039 Rev.00		Yes		
Goodwe	GW3648-EM	Hybrid PV inverter grid-tied	TUV Rheinland	2017/07/14		50085060 001	AK 50383738 0001		Yes		
Goodwe	GW36K-MT	Grid-tied PV inverter	Bureau Veritas	2020/03/05		PVZA181008N021-R1	1888AP1008N021015		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW40K-ET-10	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/17		CN232JBD 001	AK 50626466 0001		Yes		
Goodwe	GW4K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609		Yes		
Goodwe	GW5000-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW5000M-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW5000S-BP	Battery based inverter grid-tied	TUV Rheinland	2018/11/12		50180648 001	AK 50419930 0001		Yes		
Goodwe	GW5000-SBP-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW5048D-ES	Hybrid PV inverter grid-tied	TUV SUD	2018/11/12		704091815302-00	D 083373 0039 Rev.00		Yes		
Goodwe	GW5048-EM	Hybrid PV inverter grid-tied	TUV Rheinland	2017/07/14		50085060 001	AK 50383738 0001		Yes		
Goodwe	GW50K-ET-10	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/17		CN232JBD 001	AK 50626466 0001		Yes		
Goodwe	GW50K-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06		PVZA180903N057-R2	1888AP0903N057004		Yes		
Goodwe	GW50KN-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06		PVZA180903N057-R2	1888AP0903N057004		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW50KS-MT	Grid-tied PV inverter	TUV NORD & Donguan Balun	2022/06/07		TRPVP11058/21E/02	COCPPV11058/21E-04		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW5K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609		Yes		
Goodwe	GW5K-ET	Hybrid PV inverter grid-tied	Bureau Veritas	2019/05/23		PVZA190507N014	1988AP0507N014001		Yes		
Goodwe	GW6000-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW6000M-ES-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW6000-SBP-20	Grid-tied PV inverter	TUV Rheinland	2022/07/06		CN22SCQU 001	AK 50550767 0001		Yes		
Goodwe	GW60K-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06		PVZA180903N057-R2	1888AP0903N057004		Yes		

Goodwe	GW60KN-MT	Grid-tied PV inverter	Bureau Veritas	2022/05/06		PVZA180903N057-R2	1888AP0903N057004		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW60KS-MT	Grid-tied PV inverter	TÜV NORD & Donguan Balun	2022/06/07		TRPVP11058/21E/02	COCPPV11058/21E-04		Yes	Yes	The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW6K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609				
Goodwe	GW80K-MT	Grid-tied PV inverter	Bureau Veritas	2022/08/10		PVZA191217N016-R2	2288AP080035001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Goodwe	GW8K-DT	Grid-tied PV inverter	Bureau Veritas	2019/11/20		ZEM-190C0893FTSHP	U19-0609		Yes		
Goodwe	GW8K-ET	Hybrid PV inverter grid-tied	Bureau Veritas	2019/05/23		PVZA190507N014	1988AP0507N014001		Yes		
Greenich	GR-3.6K1P-L-PRO	Grid-tied PV inverter	TUV SUD	2023/08/29		704092367601-00	D 122220 0003 Rev.00		Yes		
Greenich	GR-3K1P-L-PRO	Grid-tied PV inverter	TUV SUD	2023/08/29		704092367601-00	D 122220 0003 Rev.00		Yes		
Greenich	GR-5K1P-L-PRO	Grid-tied PV inverter	TUV SUD	2023/08/29		704092367601-00	D 122220 0003 Rev.00		Yes		
Greenich	GR-6K1P-L-PRO	Grid-tied PV inverter	TUV SUD	2023/08/29		704092367601-00	D 122220 0003 Rev.00		Yes		
Greenich	GR-8K1P-L-PRO	Grid-tied PV inverter	TUV SUD	2023/08/29		704092367601-00	D 122220 0003 Rev.00		Yes		
Growatt	WIT 63K-AU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	MAX 100KTL3-X LV	Hybrid PV inverter grid-tied	Intertek	2023/11/23		230908087GZU-001	CN-PV-230647		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. Applicant requirements: List only this model.
Growatt	MAX 110KTL3-X LV	Grid-tied PV inverter	Intertek	2023/11/23		230908087GZU-001	CN-PV-230647		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. Applicant requirements: List only this model.
Growatt	MAX 120KTL3-X LV	Grid-tied PV inverter	Intertek	2023/11/23		230908087GZU-001	CN-PV-230647		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. Applicant requirements: List only this model.
Growatt	MAX 125KTL3-X LV	Grid-tied PV inverter	Intertek	2023/11/23		230908087GZU-001	CN-PV-230647		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used. Applicant requirements: List only this model.
Growatt	SPH10000TL-HU	Hybrid PV inverter grid-tied	TUV NORD & Donguan Balun	2023/12/12		TRPVP05109/238/01	COCPPV05109/238-01		Yes	Yes	
Growatt	SPH3000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25		190719102GZU-001	CN-PV-190037		Yes		
Growatt	SPH3600TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25		190719102GZU-001	CN-PV-190037		Yes	Yes	
Growatt	SPH4000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25		190719102GZU-001	CN-PV-190037		Yes	Yes	
Growatt	SPH4600TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25		190719102GZU-001	CN-PV-190037		Yes	Yes	
Growatt	SPH5000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25		190719102GZU-001	CN-PV-190037		Yes	Yes	
Growatt	SPH6000TL BL-UP	Hybrid PV inverter grid-tied	Intertek	2019/10/25		190719102GZU-001	CN-PV-190037		Yes	Yes	
Growatt	WIT 100K-AE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes	Yes	
Growatt	WIT 100K-AU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 100K-H	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 100K-HE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 100K-HU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 50K-AE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 50K-AU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 50K-H	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 50K-HE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 50K-HU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 63K-AE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 63K-H	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 63K-HE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 63K-HU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 75K-AE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 75K-AU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 75K-H	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 75K-HE	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growatt	WIT 75K-HU	Hybrid PV inverter grid-tied	Intertek	2023/12/29		2205091110GZU-001	CN-PV-230712		Yes		
Growcol	GC 10KHB-210-T/EU	Hybrid PV inverter grid-tied	TUV SUD	2023/05/09		64.290.23.30471.01	D 118596 0002 Rev. 00		Yes		
Growcol	GC 3K6HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/04/13		CN23v6TU 001	AK 50580182 0001		Yes		
Growcol	GC 5KHB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/04/13		CN23v6TU 001	AK 50580182 0001		Yes		
Growcol	GC 6KHB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/04/13		CN23v6TU 001	AK 50580182 0001		Yes		
Growcol	GC 8KHB-210-T/EU	Hybrid PV inverter grid-tied	TUV SUD	2023/05/09		64.290.23.30471.01	D 118596 0002 Rev. 00		Yes		
Growcol	GHYper-3000	Hybrid PV inverter grid-tied	Dekra	2021/08/20		6111798.51	6111798.02AOC		Yes		
Growcol	GHYper-3680	Hybrid PV inverter grid-tied	Dekra	2021/08/20		6111798.51	6111798.02AOC		Yes		
Growcol	GHYper-5000	Hybrid PV inverter grid-tied	Dekra	2021/08/20		6111798.51	6111798.02AOC		Yes		
Growcol	GW8KS3	Hybrid PV inverter grid-tied	TUV SUD	2022/10/14		64.290.22.31173.01	D 118596 0003 Rev.00		Yes		
Growcol	GW-MPS0030	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP04004/22E01	COCPPV04002/22E-01		Yes		
Growcol	GW-MPS0050	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP04004/22E01	COCPPV04002/22E-01		Yes		
Growcol	GW-MPS0100	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP04004/22E01	COCPPV04002/22E-01		Yes		
Growcol	GW-MPS0150	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/05/24		TRPVP04004/22E01	COCPPV04002/22E-01		Yes		
Growcol	GW-MPS0250	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/23		CN229F6J 003	AK 50573567 0001		Yes		
Growcol	GW-MPS0500	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/23		CN229F6J 003	AK 50573567 0001		Yes		
Growcol	GX100KT	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX100KT-F	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX110KT	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX110KT-F	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX136KT-L	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX136KT-LF	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX136KT-X	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX136KT-XF	Grid-tied PV inverter	Intertek	2022/06/27		220307041GZU-001, Rev 1	CN-PV-220070R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX25KT	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX25KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX30KT	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX30KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX33KT	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX33KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX36KT	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX36KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX40KT	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX40KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120058GZU-001, Rev 1	CN-PV-220040R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX50KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX50KTL	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.

Growcol	GX50KTL-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX50KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX60KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX60KTL	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX60KTL-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX60KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX66KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX66KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX70KT	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Growcol	GX70KT-S	Grid-tied PV inverter	Intertek	2022/06/27		220120057GZU-001, Rev 1	CN-PV-220039R1		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
HanchuESS	CESS-HY-25K	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
HanchuESS	CESS-HY-30K	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
HanchuESS	CESS-HY-36K	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
HanchuESS	CESS-HY-40K	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
HanchuESS	CESS-HY-40K-P	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
HanchuESS	CESS-HY-50K	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
HanchuESS	CESS-HY-50K-P	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/07/05		HC24041501001-EG-ZA-001	HC24041501001-EG-ZA-V001		Yes		
Hiconics	HEC-S 3K	Hybrid PV inverter grid-tied	TUV SUD	2024/04/03		64.290.24.30073.01	D 109906 0057 Rev. 00		Yes		
Hiconics	HEC-S 5K	Hybrid PV inverter grid-tied	TUV SUD	2024/04/03		64.290.24.30073.01	D 109906 0057 Rev. 00		Yes		
Hinen	H1000H-EU	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/08/07		HC23122501001-EG-ZA-C001	HC23122501001-EG-ZA-C001		Yes		
Hinen	H1200H-EU	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/08/07		HC23122501001-EG-ZA-C001	HC23122501001-EG-ZA-C001		Yes		
Hinen	H3000-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/16		BL-DG2380221-201 & 401	BL-DG2380221D02		Yes		
Hinen	H3600-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/16		BL-DG2380221-201 & 401	BL-DG2380221D02		Yes		
Hinen	H4000-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/16		BL-DG2380221-201 & 401	BL-DG2380221D02		Yes		
Hinen	H4600-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/16		BL-DG2380221-201 & 401	BL-DG2380221D02		Yes		
Hinen	H5000-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/16		BL-DG2380221-201 & 401	BL-DG2380221D02		Yes		
Hinen	H6000-EU	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/16		BL-DG2380221-201 & 401	BL-DG2380221D02		Yes		
Hinen	H8000H-EU	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2024/08/07		HC23122501001-EG-ZA-C001	HC23122501001-EG-ZA-C001		Yes		
Hoymiles	HAS-3.0LV-EUG1	Battery based inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HAS-3.6LV-EUG1	Battery based inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HAS-4.6LV-EUG1	Battery based inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HAS-5.0LV-EUG1	Battery based inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HAT-10.0HV-EUG1	Battery based inverter grid-tied	Dongguan Balun	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HAT-12.0HV-EUG1	Battery based inverter grid-tied	Dongguan Balun	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HAT-5.0HV-EUG1	Battery based inverter grid-tied	Dongguan Balun	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HAT-6.0HV-EUG1	Battery based inverter grid-tied	Dongguan Balun	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HAT-8.0HV-EUG1	Battery based inverter grid-tied	Dongguan Balun	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HM-1000	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2023/12/20		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes		
Hoymiles	HM-1000T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2023/12/20		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes		
Hoymiles	HM-1200	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2023/12/20		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes		
Hoymiles	HM-1200T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2023/12/20		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes		
Hoymiles	HM-1500	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2023/12/20		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes		
Hoymiles	HM-1500T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2023/12/20		TRPVP03078/21B/01	COCPPV03078/21B-01		Yes		
Hoymiles	HM-500	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-500T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-600	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-600T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-700	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-700T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-800	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HM-800T	Grid-tied PV inverter	TUV NORD & Dongguan Balun	2021/11/19		TRPVP03078/21B/02	COCPPV03078/21B-02		Yes		
Hoymiles	HYS-10.0LV-EUG2	Hybrid PV inverter grid-tied	TUV NORD	2023/12/20		TRPVP08096/23E/01	COCPPV08096/23E-01		Yes		
Hoymiles	HYS-12.0LV-EUG2	Hybrid PV inverter grid-tied	TUV NORD	2023/12/20		TRPVP08096/23E/01	COCPPV08096/23E-01		Yes		
Hoymiles	HYS-3.0LV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HYS-3.6LV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HYS-4.6LV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HYS-5.0LV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HYS-6.0LV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/01	COCPPV05120/23E-01		Yes		
Hoymiles	HYS-8.0LV-EUG2	Hybrid PV inverter grid-tied	TUV NORD	2023/12/20		TRPVP08096/23E/01	COCPPV08096/23E-01		Yes		
Hoymiles	HYT-10.0HV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HYT-12.0HV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HYT-5.0HV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HYT-6.0HV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	HYT-8.0HV-EUG1	Hybrid PV inverter grid-tied	TUV NORD	2023/10/23		TRPVP05120/23E/02	COCPPV05120/23E-02		Yes		
Hoymiles	MI-1000	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSH	U18-0435		Yes		
Hoymiles	MI-1000T	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSH	U18-0435		Yes		
Hoymiles	MI-1200	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSH	U18-0435		Yes		
Hoymiles	MI-1200T	Grid-tied PV inverter	Bureau Veritas	2018/07/27		ZEM-18AP0889FCSH	U18-0435		Yes		
Hoymiles	MI-500	Grid-tied PV inverter	Bureau Veritas	2018/07/10		BMH-18JA0680FCSP-R1	U18-0374		Yes		Hoymiles MI micro inverters are not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided in the photovoltaic system with appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Hoymiles	MI-600	Grid-tied PV inverter	Bureau Veritas	2018/07/10		BMH-18JA0680FCSP-R1	U18-0374		Yes		Hoymiles MI micro inverters are not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided in the photovoltaic system with appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Hoymiles	MI-700	Grid-tied PV inverter	Bureau Veritas	2018/07/10		BMH-18JA0680FCSP-R1	U18-0374		Yes		Hoymiles MI micro inverters are not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided in the photovoltaic system with appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Huawei	LUNA2000-100KTL-M1	Grid-tied PV inverter	Intertek	2023/04/04		230103213GZU-001	CN-PV-230156		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-100KTL-M1	Grid-tied PV inverter	Bureau Veritas	2020/05/29		PVZA200521N034	2088AP0521N034001		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-10K-LC0	Hybrid PV inverter grid-tied	Intertek	2023/08/23		230209049GZU-001	CN-PV-230487		Yes		
Huawei	SUN 2000-10KTL-M0	Hybrid PV inverter grid-tied	TUV SUD	2021/08/13		704092106508-00	D 041829 4613 Rev 00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Huawei	SUN 2000-10KTL-M0	Grid-tied PV inverter	Bureau Veritas	2021/09/07		PVZA190424N048-R1	1988AP0424048002		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.

[illegible]

INVT	IMARS XD4KTL	Hybrid PV inverter grid-tied	Intertek	2023/09/12		230209064GZU-001	CN-PV-230531		Yes		
INVT	IMARS XD5KTL	Hybrid PV inverter grid-tied	Intertek	2023/09/12		230209064GZU-001	CN-PV-230531		Yes		
INVT	IMARS XD6KTL	Hybrid PV inverter grid-tied	Intertek	2023/09/12		230209064GZU-001	CN-PV-230531		Yes		
iPotisEdge	IPS-3.6K-L60-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-3.6K-L60-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-4.6K-L120-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-4.6K-L60-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-5K-L120-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-5K-L60-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-6K-L120-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
iPotisEdge	IPS-6K-L60-S	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/07		CN23R9NMK 001	AK 50592898 0001		Yes		
Jinko	JKH100LTA	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2023/03/08		TRPVP01087/23E/01	COCPPV01087/23E-01		Yes		
Jinko	JKH150LTA	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2023/03/08		TRPVP01087/23E/01	COCPPV01087/23E-01		Yes		
Jinko	JKH250LTA	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/21		CN229F6J 002	AK 5057 4863 0001		Yes		
Jinko	JKH30LTA	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2023/03/08		TRPVP01087/23E/01	COCPPV01087/23E-01		Yes		
Jinko	JKH500LTA	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/21		CN229F6J 002	AK 5057 4863 0001		Yes		
Jinko	JKH50LTA	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2023/03/08		TRPVP01087/23E/01	COCPPV01087/23E-01		Yes		
Jinko	JKS-3.6HLVS-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/04/14		64.290.23.30521.01	D 118443 0019 Rev.00		Yes		
Jinko	JKS-3HLVS-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/04/14		64.290.23.30521.01	D 118443 0019 Rev.00		Yes		
Jinko	JKS-4.6HLVS-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/04/14		64.290.23.30521.01	D 118443 0019 Rev.00		Yes		
Jinko	JKS-4HLVS-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/04/14		64.290.23.30521.01	D 118443 0019 Rev.00		Yes		
Jinko	JKS-5HLVS-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/04/14		64.290.23.30521.01	D 118443 0019 Rev.00		Yes		
Jinko	JKS-6HLVS-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/04/14		64.290.23.30521.01	D 118443 0019 Rev.00		Yes		
Kehua	BCS100K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22		64.290.22.30151.01	D 115067 0036 Rev.00		Yes		The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kehua	BCS250K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22		64.290.22.30151.01	D 115067 0036 Rev.00		Yes		The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kehua	BCS500K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22		64.290.22.30151.01	D 115067 0036 Rev.00		Yes		The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
Kehua	BCSS50K-A	Battery based inverter grid-tied	TÜV SÜD	2022/09/22		64.290.22.30151.01	D 115067 0036 Rev.00		Yes		The energy storage inverter is not equipped with integrated network and system (NS) protection. External to the converter NS protection required with a City listed NS grid protection voltage and frequency relay and appropriately sized two in series contactors according to NRS 097-2-1 requirements and default settings.
KNYEE	LH6K-SL	Hybrid PV inverter grid-tied	Intertek	2023/09/14		2308A0281SHA-001	CN-PV-230529		Yes		Applicant requirements: List only this model.
KNYEE	LH6K-SL	Hybrid PV inverter grid-tied	Intertek	2023/09/14		2308A0281SHA-001	CN-PV-230529		Yes		Applicant requirements: List only this model.
Kodak	Kodak H3.0	Hybrid PV inverter grid-tied	TUV Rheinland	2019/12/17		50173405 002	AK 50454890 0001		Yes		
Kodak	Kodak H3.6	Hybrid PV inverter grid-tied	TUV Rheinland	2019/12/17		50173405 002	AK 50454890 0001		Yes		
Kodak	Kodak H4.6	Hybrid PV inverter grid-tied	TUV Rheinland	2019/12/17		50173405 002	AK 50454890 0001		Yes		
Kodak	Kodak I3.0	Grid-tied PV inverter	Dekra	2019/12/10		6065813.50	6065813.01AOC		Yes		
Kodak	Kodak I3.6	Grid-tied PV inverter	Dekra	2019/12/10		6065813.50	6065813.01AOC		Yes		
Kodak	Kodak I4.6	Grid-tied PV inverter	Dekra	2019/12/10		6065813.50	6065813.01AOC		Yes		
Koyoe	KY-1Hybrid-5k0-H-A	Hybrid PV inverter grid-tied	Intertek	2021/01/22		201102063GZU-001	CN-PV-210016		Yes		
Koyoe	KY-1Hybrid-5k0-H-A	Hybrid PV inverter grid-tied	Intertek	2021/06/21		210525156GZU-001	CN-PV-210154		Yes		
Koyoe	KY-ESS30KH	Hybrid PV inverter grid-tied	TUV NORD	2023/07/03		TRPVP03166/23E/01	COCPPV03166/23E-02		Yes		
Koyoe	KY-ESS42KH	Hybrid PV inverter grid-tied	TUV NORD	2023/07/03		TRPVP03166/23E/01	COCPPV03166/23E-02		Yes		
Koyoe	KY-ESS50KH	Hybrid PV inverter grid-tied	TUV NORD	2023/07/03		TRPVP03166/23E/01	COCPPV03166/23E-02		Yes		
Koyoe	KY-ESS60KH	Hybrid PV inverter grid-tied	TUV NORD	2023/07/03		TRPVP03166/23E/01	COCPPV03166/23E-02		Yes		
Koyoe	KY-ESS70KH	Hybrid PV inverter grid-tied	TUV NORD	2023/07/03		TRPVP03166/23E/01	COCPPV03166/23E-02		Yes		
Koyoe	KY-ESS80KH	Hybrid PV inverter grid-tied	TUV NORD	2023/07/03		TRPVP03166/23E/01	COCPPV03166/23E-02		Yes		
Koyoe	KY-EST06KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST06KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST08KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST08KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST10KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST10KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST12KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST12KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST15KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST15KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST17KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST17KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST20KH	Hybrid PV inverter grid-tied	TUV NORD	2021/10/15		TRPVP04039/21E/04	COCPPV04039/21E-01		Yes		
Koyoe	KY-EST20KH-A	Hybrid PV inverter grid-tied	TUV NORD	2021/12/30		TRPVP04039/21E/09	COCPPV04039/21E-02		Yes		
Koyoe	KY-EST30KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
Koyoe	KY-EST35KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
Koyoe	KY-EST40KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
Koyoe	KY-EST45KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
Koyoe	KY-EST50KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
Koyoe	KY-EST55KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
Koyoe	KY-EST60KH	Hybrid PV inverter grid-tied	TUV NORD	2023/05/31		TRPVP03166/23E/02	COCPPV03166/23E-01		Yes		
KSTAR	Blue-G 3000D	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3000D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3000D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3000S	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3000S-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3600D	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3600D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 3600D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4000D	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4000D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4000D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4200D	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4200D-M0	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4200D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4600D	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-G 4600D-M1	Grid-tied PV inverter	TUV SÜD	2021/09/23		64.290.21.30004.03	D 075386 0137 Rev.02		Yes		
KSTAR	Blue-S 3680D	Hybrid PV inverter grid-tied	TUV SÜD	2021/09/23		64.290.20.30989.03	D 075386 0136 Rev.02		Yes		

Applicant requirements: List Model ME-HS5L-A only

Ohm	OHM-5K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26		BL-SZ1910095-B02	BL-SZ1910095-D02	Yes			
Ohm	OHM-6K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26		BL-SZ1910095-B02	BL-SZ1910095-D02	Yes			
Ohm	OHM-7.6K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26		BL-SZ1910095-B02	BL-SZ1910095-D02	Yes			
Ohm	OHM-8K-W	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/02/26		BL-SZ1910095-B02	BL-SZ1910095-D02	Yes			
Onesto	OST 4600HB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 4600HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 4K6AC	Battery based inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 5000HB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 5000HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 5KAC	Battery based inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 6000HB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 6000HB-60	Hybrid PV inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Onesto	OST 6KAC	Battery based inverter grid-tied	TUV Rheinland	2023/05/11		CN23UTJN 001	AK 50580973 0001		Yes		
Ouco	M3K6ES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25		64.290.22.30047.01	D 115420 0001 Rev.00		Yes		
Ouco	M3KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25		64.290.22.30047.01	D 115420 0001 Rev.00		Yes		
Ouco	M4K6ES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25		64.290.22.30047.01	D 115420 0001 Rev.00		Yes		
Ouco	M4KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25		64.290.22.30047.01	D 115420 0001 Rev.00		Yes		
Ouco	M5KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25		64.290.22.30047.01	D 115420 0001 Rev.00		Yes		
Ouco	M6KES	Hybrid PV inverter grid-tied	TUV SUD	2022/01/25		64.290.22.30047.01	D 115420 0001 Rev.00		Yes		
Ouco	M8KDS	Hybrid PV inverter grid-tied	TUV SUD	2022/01/27		64.290.22.30048.01	D 115420 0002 Rev.00		Yes		
Powercent	PC-INV-SPB5K	Hybrid PV inverter grid-tied	Intertek	2023/08/02		230501592SHA-001 Revision 1	CN-PV-230318R1		Yes		
Powercent	PC-INV-SPH3.6K	Hybrid PV inverter grid-tied	Intertek	2023/08/02		230501592SHA-001 Revision 1	CN-PV-230318R1		Yes		
Powercent	PC-INV-SPH5K	Hybrid PV inverter grid-tied	Intertek	2023/08/02		230501592SHA-001 Revision 1	CN-PV-230318R1		Yes		
Powertannk	GH-3K6HL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11		64.290.22.31476.01	D 110578 0002 Rev.00		Yes		
Powertannk	GH-3KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11		64.290.22.31476.01	D 110578 0002 Rev.00		Yes		
Powertannk	GH-4K6HL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11		64.290.22.31476.01	D 110578 0002 Rev.00		Yes		
Powertannk	GH-4KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11		64.290.22.31476.01	D 110578 0002 Rev.00		Yes		
Powertannk	GH-5KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11		64.290.22.31476.01	D 110578 0002 Rev.00		Yes		
Powertannk	GH-6KHL	Hybrid PV inverter grid-tied	TUV SUD	2022/11/11		64.290.22.31476.01	D 110578 0002 Rev.00		Yes		
QWWi	CVG1QV-5KW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVG2QV	Hybrid PV inverter grid-tied	TUV SUD	2024/06/17		64.290.24.30289 01 001	D 122482 0002 Rev. 00		Yes		
QWWi	CVG3QV	Hybrid PV inverter grid-tied	TUV SUD	2024/06/17		64.290.24.30289 01 001	D 122482 0002 Rev. 00		Yes		
QWWi	CVG5QV-3K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVG6QV-3K68W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVG7QV-4K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVG8QV-5KW60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVG9QV-6KW60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVGAQV-4KGW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
QWWi	CVGBQV-6KW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Rentech	HYD 3000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	HYD 3680-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	HYD 4000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	HYD 4600-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	HYD 5000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	HYD 5500-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	HYD 6000-EP	Hybrid PV inverter grid-tied	Intertek	2020/12/22		201207035GZU-001	CN-PV-200172	Yes			
Rentech	INFINISOLAR PLUS 5 kW	Hybrid PV inverter grid-tied	Bureau Veritas	2021/02/20		PVZA2101WDG0269	2188AP0269001		Yes		
Royel	RH 10K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		221102934SHA-004	CN-PV-230379		Yes		
Royel	RH 3.6K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		2305A0674SHA-001	CN-PV-230383		Yes		
Royel	RH 4.6K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		2305A0674SHA-001	CN-PV-230383		Yes		
Royel	RH 4K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		2305A0674SHA-001	CN-PV-230383		Yes		
Royel	RH 5K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		2305A0674SHA-001	CN-PV-230383		Yes		
Royel	RH 6K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		2305A0674SHA-001	CN-PV-230383		Yes		
Royel	RH 7K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		221102934SHA-004	CN-PV-230379		Yes		
Royel	RH 8K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		221102934SHA-004	CN-PV-230379		Yes		
Royel	RH 9K-1PLVG1-EU	Hybrid PV inverter grid-tied	Intertek	2023/06/30		221102934SHA-004	CN-PV-230379		Yes		
RoyPow	SUN3600S-SE	Hybrid PV inverter grid-tied	TUV SUD	2023/06/29		64.290.23.30701.01	D 117120 0005 Rev.00		Yes		
RoyPow	SUN4600S-SE	Hybrid PV inverter grid-tied	TUV SUD	2023/06/29		64.290.23.30701.01	D 117120 0005 Rev.00		Yes		
RoyPow	SUN5000S-SE	Hybrid PV inverter grid-tied	TUV SUD	2023/06/29		64.290.23.30701.01	D 117120 0005 Rev.00		Yes		
RoyPow	SUN6000S-SE	Hybrid PV inverter grid-tied	TUV SUD	2023/06/29		64.290.23.30701.01	D 117120 0005 Rev.00		Yes		
SAJ	CH2-29.9K-T4	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/09		AK 50607862 0001	CN23IDBQ 001		Yes		
SAJ	CH2-29.9K-T4-P	Hybrid PV inverter grid-tied	Shenzhen Chengxin Technology Service	2024/04/29		CTS20240092-S	CTS20240092-C		Yes		
SAJ	CH2-30K-T4	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/09		AK 50607862 0001	CN23IDBQ 001		Yes		
SAJ	CH2-30K-T4-P	Hybrid PV inverter grid-tied	Shenzhen Chengxin Technology Service	2024/04/29		CTS20240092-S	CTS20240092-C		Yes		
SAJ	CH2-40K-T5	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/09		AK 50607862 0001	CN23IDBQ 001		Yes		
SAJ	CH2-40K-T5-P	Hybrid PV inverter grid-tied	Shenzhen Chengxin Technology Service	2024/04/29		CTS20240092-S	CTS20240092-C		Yes		
SAJ	CH2-50K-T6	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/09		AK 50607862 0001	CN23IDBQ 001		Yes		
SAJ	CH2-50K-T6-P	Hybrid PV inverter grid-tied	Shenzhen Chengxin Technology Service	2024/04/29		CTS20240092-S	CTS20240092-C		Yes		
SAJ	CH2-63K-T6	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/09		AK 50607862 0001	CN23IDBQ 001		Yes		
SAJ	CH2-63K-T6-P	Hybrid PV inverter grid-tied	Shenzhen Chengxin Technology Service	2024/04/29		CTS20240092-S	CTS20240092-C		Yes		
SAJ	H1-3.6K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
SAJ	H1-3K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
SAJ	H1-4.6K-LS2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
SAJ	H1-4.6K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
SAJ	H1-4K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
SAJ	H1-5K-LS2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
SAJ	H1-5K-S2	Hybrid PV inverter grid-tied	TUV SUD	2022/11/18		64.290.20.30788.02	D 077831 0019 Rev.01		Yes		
Salvare	Salvare 10 PRO	Hybrid PV inverter grid-tied	TUV SUD	2023/11/10		64.290.23.31727.01	D 123264 0001 Rev.00		Yes		
Salvare	Salvare 8 PRO	Hybrid PV inverter grid-tied	TUV SUD	2023/11/10		64.290.23.31727.01	D 123264 0001 Rev.00		Yes		
Salvare	Salvare Pro 6kW	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/01		CN2322U7 001	AK 50609510 0001		Yes		
Schneider	CL 33	Grid-tied PV inverter	TUV NORD & Shenzhen Balun	2021/02/09		TRPVP11115/20B/01_R2	COCPPV11115/20B_R1	Yes			The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Schneider	CL50	Grid-tied PV inverter	TUV NORD & Shenzhen Balun	2021/02/09		TRPVP11115/20B/01_R2	COCPPV11115/20B_R1	Yes			The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Schneider	Conext CL-60E	Grid-tied PV inverter	TUV SUD	2021/02/09		701261703501-01	D 18 01 98208 006	Yes			
Schneider	XW+8548E	Battery based inverter grid-tied	TUV Rheinland	2020/08/11		50328684 002	AK 50477341 0001	Yes			

Sermatec	SMT-10K-TL-TH	Hybrid PV inverter grid-tied	TUV SUD	2019/07/25		64.290.18.04743.01	D 102650 0009	Yes			
Sermatec	SMT-5K-TL-LV	Hybrid PV inverter grid-tied	TUV SUD	2019/06/25		64.290.19.01426.01	D 102650 0007	Yes			
Sigenergy	Sigen PV Max 17.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	Sigen PV Max 10.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	Sigen PV Max 12.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	Sigen PV Max 25.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	SigenStor EC 10.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	SigenStor EC 12.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	SigenStor EC 20.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	SigenStor EC 25.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	Sigen Hybrid 10.0 SP	Hybrid PV inverter grid-tied	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	Sigen Hybrid 12.0 SP	Hybrid PV inverter grid-tied	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	Sigen Hybrid 8.0 SP	Hybrid PV inverter grid-tied	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	Sigen PV Max 10.0 SP	Grid-tied PV inverter	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	Sigen PV Max 12.0 SP	Grid-tied PV inverter	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	Sigen PV Max 15.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012	Yes			
Sigenergy	Sigen PV Max 20.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012	Yes			
Sigenergy	Sigen PV Max 8.0 SP	Grid-tied PV inverter	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	Sigen PV Max 8.0 TP	Grid-tied PV inverter	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012	Yes			
Sigenergy	SigenStor EC 10.0 SP	Hybrid PV inverter grid-tied	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	SigenStor EC 12.0 SP	Hybrid PV inverter grid-tied	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	SigenStor EC 15.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	SigenStor EC 17.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sigenergy	SigenStor EC 3.0 SP	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/19		CN23Q55Z 001	AK 50598929 0001		Yes		
Sigenergy	SigenStor EC 3.6 SP	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/19		CN23Q55Z 001	AK 50598929 0001		Yes		
Sigenergy	SigenStor EC 4.0 SP	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/19		CN23Q55Z 001	AK 50598929 0001		Yes		
Sigenergy	SigenStor EC 4.6 SP	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/19		CN23Q55Z 001	AK 50598929 0001		Yes		
Sigenergy	SigenStor EC 5.0 SP	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/19		CN23Q55Z 001	AK 50598929 0001		Yes		
Sigenergy	SigenStor EC 6.0 SP	Hybrid PV inverter grid-tied	TUV Rheinland	2023/08/19		CN23Q55Z 001	AK 50598929 0001		Yes		
Sigenergy	SigenStor EC 8.0 SP	Hybrid PV inverter grid-tied	Intertek	2024/04/16		240306020GZU-001	CN-PVES-240141			Yes	
Sigenergy	SigenStor EC 8.0 TP	Hybrid PV inverter grid-tied	Intertek	2024/01/09		230705154GZU-001	CN-PV-240012		Yes		
Sineng	SN100PT	Grid-tied PV inverter	TUV Rheinland	2024/06/03		CN24PPJN 001	AK 50633023 0001			Yes	
Sineng	SN110PT	Grid-tied PV inverter	TUV Rheinland	2024/06/03		CN24PPJN 001	AK 50633023 0001			Yes	
Sineng	SN110PT-B	Grid-tied PV inverter	TUV Rheinland	2024/06/03		CN24PPJN 001	AK 50633023 0001			Yes	
Sineng	SN125PT	Grid-tied PV inverter	TUV Rheinland	2024/06/03		CN24PPJN 001	AK 50633023 0001			Yes	
Sineng	SN3.0-HS	Hybrid PV inverter grid-tied	TUV SUD	2024/01/22		70.409.23.462.15-00	No.D 091566 0071 Rev.00		Yes		
Sineng	SN3.68HS	Hybrid PV inverter grid-tied	TUV SUD	2024/01/22		70.409.23.462.15-00	No.D 091566 0071 Rev.00		Yes		
Sineng	SN4.0HS	Hybrid PV inverter grid-tied	TUV SUD	2024/01/22		70.409.23.462.15-00	No.D 091566 0071 Rev.00		Yes		
Sineng	SN5.0HS	Hybrid PV inverter grid-tied	TUV SUD	2024/01/22		70.409.23.462.15-00	No.D 091566 0071 Rev.00		Yes		
Sineng	SN50PT	Grid-tied PV inverter	TUV Rheinland	2024/06/26		CN24RO4C 001	AK 50636070 0001			Yes	
Sineng	SN50PT-B	Grid-tied PV inverter	TUV Rheinland	2024/06/26		CN24RO4C 001	AK 50636070 0001			Yes	
Sineng	SN6.0HS	Hybrid PV inverter grid-tied	TUV SUD	2024/01/22		70.409.23.462.15-00	No.D 091566 0071 Rev.00		Yes		
Sineng	SN60PT	Grid-tied PV inverter	TUV Rheinland	2024/06/26		CN24RO4C 001	AK 50636070 0001			Yes	
Sineng	SP-120K-BL	Grid-tied PV inverter	TUV SUD	2022/12/28		70.409.22.302.06-00 A1	D 091566 0040 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sineng	SP-120K-L	Grid-tied PV inverter	TUV SUD	2022/12/28		70.409.22.302.06-00 A1	D 091566 0040 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sinexcel	PWG2-100K-EX	Hybrid PV inverter grid-tied	TUV SUD	2021/09/10		64.290.21.30201.02	D 076777 0016 Rev. 01		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA. Inverter not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided with appropriately sized electromechanical switches.
Sinexcel	PWG2-50K-EX	Hybrid PV inverter grid-tied	TUV SUD	2021/09/10		64.290.21.30201.02	D 076777 0016 Rev. 01		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA. Inverter not equipped with an internal disconnection device and an external City listed network and system grid protection voltage and frequency relay must be provided with appropriately sized electromechanical switches.
Sinotec	HT-5KW-A	Hybrid PV inverter grid-tied	TUV NORD	2023/12/05		TRPVP11012/23E-01	COCPPV11012/23E-01		Yes		
Sinotec	HT-6KW-A	Hybrid PV inverter grid-tied	TUV NORD	2023/12/05		TRPVP11012/23E-01	COCPPV11012/23E-01		Yes		
Sinotec	HT-8KW-A	Hybrid PV inverter grid-tied	TUV NORD	2024/01/19		TRPVP12110/23E-01	COCPPV12110/23E-01		Yes		
Sinotec	SAIO-5K	Hybrid PV inverter grid-tied	Dongguan Balun	2024/03/26		BL-DG2430558-201	BL-DG2430558D01		Yes		
Skye	HN3K6S-AH2	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN3K6S-AH2G	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN3KS-AH2	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN3KS-AH2G	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN4KS-AH2	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN4KS-AH2G	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN5KS-AH2	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN5KS-AH2G	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN6KS-AH2	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skye	HN6KS-AH2G	Hybrid PV inverter grid-tied	Dongguan Balun	2024/07/10		BL-DG2460091-201(G1) & BL-DG2460091-401(G1)	BL-DG2460091D02		Yes		
Skyworth	CVG1QV-5KW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG1SW-5KW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG2SW	Hybrid PV inverter grid-tied	TUV SUD	2024/06/17		64.290.24.30289.01 001	D 122482 0002 Rev. 00		Yes		
Skyworth	CVG3SW	Hybrid PV inverter grid-tied	TUV SUD	2024/06/17		64.290.24.30289.01 001	D 122482 0002 Rev. 00		Yes		
Skyworth	CVG5QV-3K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG5SW-3K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG6QV-3K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG6SW-3K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG7QV-4K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG7SW-4K6W60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG8QV-5KW60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG8SW-5KW60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG9QV-6KW60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVG9SW-6KW60	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVGAQV-4KW6	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		
Skyworth	CVGASW-4KW6	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23S00Q 001	AK 50614544 0001		Yes		

Skyworth	CVGBQV-6KW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23500Q 001	AK 50614544 0001		Yes		
Skyworth	CVGBSW-6KW	Hybrid PV inverter grid-tied	TUV Rheinland	2024/01/26		CN23500Q 001	AK 50614544 0001		Yes		
SMA	SB3.0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20		16TH0348-NRS 097-2-1 1	U23-0041		Yes		
SMA	SB3.6-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20		16TH0348-NRS 097-2-1 1	U23-0041		Yes		
SMA	SB4.0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20		16TH0348-NRS 097-2-1 1	U23-0041		Yes		
SMA	SB5.0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20		16TH0348-NRS 097-2-1 1	U23-0041		Yes		
SMA	SB6.0-1AV-41	Grid-tied PV inverter	Bureau Veritas	2023/01/20		16TH0348-NRS 097-2-1 1	U23-0041		Yes		
SMA	SHP75-10	Grid-tied PV inverter	Bureau Veritas	2018/09/26		14TH0075-NRS 097-2-1 3	U18-0451	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	SI4.4M-13	Battery based inverter grid-tied	Bureau Veritas	2023/08/16		13TH0287-NRS-2-1 1	U23-0695		Yes		
SMA	SI6.0M-13	Battery based inverter grid-tied	Bureau Veritas	2023/08/16		13TH0287-NRS-2-1 1	U23-0695		Yes		
SMA	SI8.0M-13	Battery based inverter grid-tied	Bureau Veritas	2023/08/16		13TH0287-NRS-2-1 1	U23-0695		Yes		
SMA	STP 110-60	Grid-tied PV inverter	TUV SUD	2021/01/21		704092001861-00	D 0701220019 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
SMA	STP 15000TL-30	Grid-tied PV inverter	Bureau Veritas	2020/08/13		14TH0304-NRS 097-2-1-2017 0	U20-0641		Yes		
SMA	STP 20000TL-30	Grid-tied PV inverter	Bureau Veritas	2020/08/13		14TH0304-NRS 097-2-1-2017 0	U20-0641		Yes		
SMA	STP 25000TL-30	Grid-tied PV inverter	Bureau Veritas	2020/08/13		14TH0304-NRS 097-2-1-2017 0	U20-0641		Yes		
SMA	STP10.0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14		18TH0325-NRS-2-1 0	U21-0661		Yes		
SMA	STP10.0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21		CN210918 001	AK 50510847 0001		Yes		
SMA	STP12-50	Grid-tied PV inverter	TUV SUD	2023/04/03		713254379-006	ESY 070122 0044 Rev.00		Yes		
SMA	STP15-50	Grid-tied PV inverter	TUV SUD	2023/04/03		713254379-006	ESY 070122 0044 Rev.00		Yes		
SMA	STP20-50	Grid-tied PV inverter	TUV SUD	2023/04/03		713254379-006	ESY 070122 0044 Rev.00		Yes		
SMA	STP25-50	Grid-tied PV inverter	TUV SUD	2023/04/03		713254379-006	ESY 070122 0044 Rev.00		Yes		
SMA	STP3.0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14		18TH0325-NRS-2-1 0	U21-0661		Yes		
SMA	STP4.0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14		18TH0325-NRS-2-1 0	U21-0661		Yes		
SMA	STP5.0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14		18TH0325-NRS-2-1 0	U21-0661		Yes		
SMA	STP5.0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21		CN210918 001	AK 50510847 0001		Yes		
SMA	STP50-40	Grid-tied PV inverter	Bureau Veritas	2023/03/08		17TH0199-NRS 097-2-1 4	U23-0185		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STP50-41	Grid-tied PV inverter	Bureau Veritas	2023/03/08		17TH0199-NRS 097-2-1 4	U23-0185		Yes		Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STP6.0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14		18TH0325-NRS-2-1 0	U21-0661		Yes		
SMA	STP6.0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21		CN210918 001	AK 50510847 0001		Yes		
SMA	STP60-10	Grid-tied PV inverter	Bureau Veritas	2018/09/26		14TH0075-NRS 097-2-1 3	U18-0451	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SMA	STP8.0-3AV-40	Grid-tied PV inverter	Bureau Veritas	2021/07/14		18TH0325-NRS-2-1 0	U21-0661		Yes		
SMA	STP8.0-3SE-40	Hybrid PV inverter grid-tied	TUV Rheinland	2022/02/21		CN210918 001	AK 50510847 0001		Yes		
SMA	STPS 60-10	Hybrid PV inverter grid-tied	Bureau Veritas	2018/09/26		14TH0075-NRS 097-2-1 3	U18-0451	Yes			Inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
Sofar Solar	3.6KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	3KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	4.6KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	4KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	5000TL	Grid-tied PV inverter	Intertek	2019/12/19		191025090GZU-001	CN-PV-190090	Yes			
Sofar Solar	5KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	5KTL-M-G3-A	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	6000TL	Grid-tied PV inverter	Intertek	2019/12/19		191025090GZU-001	CN-PV-190090	Yes			
Sofar Solar	6KTL-M-G3	Grid-tied PV inverter	Intertek	2021/08/09		210715145GZU-002	CN-PV-210185		Yes		
Sofar Solar	HYD 10KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10		BL-DG2060517-B01	BL-DG2060517D01	Yes			
Sofar Solar	HYD 15KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10		BL-DG2060517-B01	BL-DG2060517D01	Yes			
Sofar Solar	HYD 20KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10		BL-DG2060517-B01	BL-DG2060517D01	Yes			
Sofar Solar	HYD 3000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16		190603089GZU-001	190603089GZU-001	Yes			
Sofar Solar	HYD 3600-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16		190603089GZU-001	190603089GZU-001	Yes			
Sofar Solar	HYD 4000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16		190603089GZU-001	190603089GZU-001	Yes			
Sofar Solar	HYD 5000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16		190603089GZU-001	190603089GZU-001	Yes			
Sofar Solar	HYD 5KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10		BL-DG2060517-B01	BL-DG2060517D01	Yes			
Sofar Solar	HYD 6000-ES	Hybrid PV inverter grid-tied	Intertek	2019/07/16		190603089GZU-001	190603089GZU-001	Yes			
Sofar Solar	HYD 6KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10		BL-DG2060517-B01	BL-DG2060517D01	Yes			
Sofar Solar	HYD 8KTL-3PH	Hybrid PV inverter grid-tied	Shenzhen Balun	2020/07/10		BL-DG2060517-B01	BL-DG2060517D01	Yes			
SolarEdge	SE 1000H	Hybrid PV inverter grid-tied	Bureau Veritas	2023/08/23		16TH0371-NRS 097-2-1 3	U23-0587 1		Yes		
SolarEdge	SE 2200H	Hybrid PV inverter grid-tied	Bureau Veritas	2023/08/23		16TH0371-NRS 097-2-1 3	U23-0587 1		Yes		
SolarEdge	SE 4000H	Hybrid PV inverter grid-tied	Bureau Veritas	2023/08/23		16TH0371-NRS 097-2-1 3	U23-0587 1		Yes		
SolarEdge	SE 5000H	Hybrid PV inverter grid-tied	Bureau Veritas	2023/08/23		16TH0371-NRS 097-2-1 3	U23-0587 1		Yes		
SolarEdge	SE 6000H	Hybrid PV inverter grid-tied	Bureau Veritas	2023/08/23		16TH0371-NRS 097-2-1 3	U23-0587 1		Yes		
SolarEdge	SE 8000H	Hybrid PV inverter grid-tied	Bureau Veritas	2023/08/23		16TH0371-NRS 097-2-1 3	U23-0587 1		Yes		
SolarEdge	SE100K	Grid-tied PV inverter	Bureau Veritas	2021/06/07		20TH0532-NRS 097-2-1 0	U21-0499		Yes		Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE10K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE12.5K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE120K*	Grid-tied PV inverter	Bureau Veritas	2021/06/07		20TH0532-NRS 097-2-1 0	U21-0499		Yes		For both 230 V, L-N / 400Vac, L-L and 277 Vac L-N / 480 Vac L-L output, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SolarEdge	SE15K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE16K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE17K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE25K	Grid-tied PV inverter	Bureau Veritas	2020/12/19		19TH0534-NRS 097-2-1 2	U20-1043		Yes		Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE27.6K	Grid-tied PV inverter	Bureau Veritas	2020/12/19		19TH0534-NRS 097-2-1 2	U20-1043		Yes		Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE30K	Grid-tied PV inverter	Bureau Veritas	2020/12/19		19TH0534-NRS 097-2-1 2	U20-1043		Yes		For 277 Vac L-N / 480 Vac L-L grid, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer. Grid connection inverter with 230 V, L-N / 400Vac, L-L output is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE33.3K	Grid-tied PV inverter	Bureau Veritas	2020/12/19		19TH0534-NRS 097-2-1 2	U20-1043		Yes		For 277 Vac L-N / 480 Vac L-L grid, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer. Grid connection inverter with 230 V, L-N / 400Vac, L-L output is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE3K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE40K	Grid-tied PV inverter	Bureau Veritas	2020/12/19		19TH0534-NRS 097-2-1 2	U20-1043		Yes		For both 230 V, L-N / 400Vac, L-L and 277 Vac L-N / 480 Vac L-L output, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MV/LV AC transformer.
SolarEdge	SE4K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE50K	Grid-tied PV inverter	Bureau Veritas	2021/06/07		20TH0532-NRS 097-2-1 0	U21-0499		Yes		Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE55K	Grid-tied PV inverter	Bureau Veritas	2021/06/07		20TH0532-NRS 097-2-1 0	U21-0499		Yes		Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.
SolarEdge	SE5K	Grid-tied PV inverter	TUV SUD	2021/09/03		713224660 000	D 082496 0022 Rev.00		Yes		
SolarEdge	SE66.6K	Grid-tied PV inverter	Bureau Veritas	2021/06/07		20TH0532-NRS 097-2-1 0	U21-0499		Yes		Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plant.

SolarEdge	SE66.6K*	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	Model with AC output voltage 277 Vac L-N / 480 Vac L-L, is intended for grid connection with an external customer MVLV AC transformer and only for plants with Category A3: 100 kVA - 1MVA
SolarEdge	SE6K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660 000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE75K	Grid-tied PV inverter	Bureau Veritas	2021/04/01	17TH0209-NRS 097-2-1 2	U21-0295	Yes	
SolarEdge	SE7K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660 000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE80K*	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	
SolarEdge	SE82.8K	Grid-tied PV inverter	Bureau Veritas	2021/06/07	20TH0532-NRS 097-2-1 0	U21-0499	Yes	For both 230 V, L-N / 400Vac, L-L and 277 Vac L-N / 480 Vac L-L output, inverter may only be used in plants according to Category A3: 100 kVA - 1MVA and connection to the grid via an external customer MVLV AC transformer. Grid connection inverter for 230 V, L-N / 400Vac, L-L output only and is intended with and without AC transformer for Category A2 and A3 plants.
SolarEdge	SE8K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660 000	D 082496 0022 Rev.00	Yes	
SolarEdge	SE9K	Grid-tied PV inverter	TUV SUD	2021/09/03	713224660 000	D 082496 0022 Rev.00	Yes	
Solaroom	XD3K6TL	Hybrid PV inverter grid-tied	Intertek	2024/03/08	2312182228GZU-001	CN-PVES-240078	Yes	
Solaroom	XD3KTL	Hybrid PV inverter grid-tied	Intertek	2024/03/08	2312182228GZU-001	CN-PVES-240078	Yes	
Solaroom	XD4K6TL	Hybrid PV inverter grid-tied	Intertek	2024/03/08	2312182228GZU-001	CN-PVES-240078	Yes	
Solaroom	XD4KTL	Hybrid PV inverter grid-tied	Intertek	2024/03/08	2312182228GZU-001	CN-PVES-240078	Yes	
Solaroom	XD5KTL	Hybrid PV inverter grid-tied	Intertek	2024/03/08	2312182228GZU-001	CN-PVES-240078	Yes	
Solaroom	XD6KTL	Hybrid PV inverter grid-tied	Intertek	2024/03/08	2312182228GZU-001	CN-PVES-240078	Yes	
SolaX Power	SK-SU3000C	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3000C-S	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3000E	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3000E-S	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3700C	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU3700E	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU5000C	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-SU5000E	Hybrid PV inverter grid-tied	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3000C	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3000C-S	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3000E	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3000E-S	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3000R	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3000R-S	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3700C	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3700E	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3700R	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL3700R	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL5000C	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL5000E	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	SK-TL5000R	Grid-tied PV inverter	TUV SUD	2018/03/29	70.409.18.010.02-00	D 18 03 85769 043	Yes	
SolaX Power	X1-Fit-3.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-3.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-3.7-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-3.7-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-5.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-5.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-6.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-6.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-7.5-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-7.5-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Fit-3.7C	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-3.7E	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-3.7I	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-4.6C	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-4.6E	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-4.6I	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-5.0C	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-5.0E	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Fit-5.0I	Grid-tied PV inverter	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-HYB-3.7-LV	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/28	CN23JAXV 001	AK 50614395 0001	Yes	
SolaX Power	X1-HYB-3.0-LV	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/28	CN23JAXV 001	AK 50614395 0001	Yes	
SolaX Power	X1-HYB-4.0-LV	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/28	CN23JAXV 001	AK 50614395 0001	Yes	
SolaX Power	X1-HYB-4.6-LV	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/28	CN23JAXV 001	AK 50614395 0001	Yes	
SolaX Power	X1-HYB-5.0-LV	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/28	CN23JAXV 001	AK 50614395 0001	Yes	
SolaX Power	X1-HYB-6.0-LV	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/28	CN23JAXV 001	AK 50614395 0001	Yes	
SolaX Power	X1-Hybrid-3.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-3.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-3.7-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-3.7-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-5.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-5.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-6.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-6.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-7.5-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-7.5-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/30	CN218CU1 002	AK 50510554 0001	Yes	
SolaX Power	X1-Hybrid-3.0-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-D-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.0-N-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-D-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-3.7-N-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-D-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-4.6-N-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-D-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-D-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-D-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31	70.409.19.191.01-00	D 08576900055	Yes	

SolaX Power	X1-Hybrid-5.0-N-C	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31		70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-N-E	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31		70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-Hybrid-5.0-N-I	Hybrid PV inverter grid-tied	TUV SUD	2019/07/31		70.409.19.191.01-00	D 08576900055	Yes	
SolaX Power	X1-IES-3.7K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03		CN24PPWA 001	AK 50623431 0001	Yes	
SolaX Power	X1-IES-3K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03		CN24PPWA 001	AK 50623431 0001	Yes	
SolaX Power	X1-IES-4.6K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03		CN24PPWA 001	AK 50623431 0001	Yes	
SolaX Power	X1-IES-5K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03		CN24PPWA 001	AK 50623431 0001	Yes	
SolaX Power	X1-IES-6K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03		CN24PPWA 001	AK 50623431 0001	Yes	
SolaX Power	X1-IES-8K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03		CN24PPWA 001	AK 50623431 0001	Yes	
SolaX Power	X3-30.0-T-D	Grid-tied PV inverter	TUV SUD	2017/08/04		70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X3-30.0-T-N	Grid-tied PV inverter	TUV SUD	2017/08/04		70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X3-36.0-T-N	Grid-tied PV inverter	TUV SUD	2017/08/04		70.409.17.128.02-01	D 17 08 85769 026	Yes	
SolaX Power	X3-Fit -10.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -10.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -15.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -15.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -6.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -6.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -8.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit -8.0-W	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29		CN21QAQJ 002	AK 50510555 0001	Yes	
SolaX Power	X3-Fit-10.0C	Grid-tied PV inverter	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Fit-10.0E	Grid-tied PV inverter	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Fit-8.0C	Grid-tied PV inverter	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Fit-8.0E	Grid-tied PV inverter	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-FTH-100K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-FTH-110K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-FTH-120K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-FTH-125K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-FTH-136K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-FTH-150K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-FTH-80K	Grid-tied PV inverter	TUV Rheinland	2023/04/14	CN22PDK3 001	CN21PSK3 001		Yes	
SolaX Power	X3-Hybrid -10.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -10.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -12.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -12.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -15.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -15.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -5.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -5.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -6.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -6.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -8.0-D	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid -8.0-M	Hybrid PV inverter grid-tied	TUV Rheinland	2021/07/29	CN21QAQJ 002	AK 50510555 0001		Yes	
SolaX Power	X3-Hybrid-10.0-D-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-10.0-D-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-10.0-N-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-10.0-N-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-5.0-D-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-5.0-D-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-5.0-N-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-5.0-N-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-6.0-D-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-6.0-D-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-6.0-N-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-6.0-N-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-8.0-D-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-8.0-D-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-8.0-N-C	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-Hybrid-8.0-N-E	Hybrid PV inverter grid-tied	Bureau Veritas	2018/10/18	SXP-18SE2165FCSHP	U18-0570		Yes	Not intended for the use in plants > 100kVA
SolaX Power	X3-IES-10K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03	CN248PZD 001	AK 50624473 0001		Yes	
SolaX Power	X3-IES-12K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03	CN248PZD 001	AK 50624473 0001		Yes	
SolaX Power	X3-IES-15K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03	CN248PZD 001	AK 50624473 0001		Yes	
SolaX Power	X3-IES-8K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03	CN248PZD 001	AK 50624473 0001		Yes	
SolaX Power	X3-IES-6K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03	CN248PZD 001	AK 50624473 0001		Yes	
SolaX Power	X3-IES-8K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/04/03	CN248PZD 001	AK 50624473 0001		Yes	
SolaX Power	X3-ULT-15K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
SolaX Power	X3-ULT-15KP	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
SolaX Power	X3-ULT-19.9K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
SolaX Power	X3-ULT-20K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
SolaX Power	X3-ULT-20KP	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
SolaX Power	X3-ULT-25K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
SolaX Power	X3-ULT-30K	Hybrid PV inverter grid-tied	TUV Rheinland	2024/03/13	CN240UWV 001	AK 50621900 0001		Yes	
Solinteq	MHS-3.6K-30	Hybrid PV inverter grid-tied	Huachuang Technology	2023/05/17	221114BWA134-EG-ZA-001	221114BWA134-EG-ZA-C001		Yes	
Solinteq	MHS-3K-30	Hybrid PV inverter grid-tied	Huachuang Technology	2023/05/17	221114BWA134-EG-ZA-001	221114BWA134-EG-ZA-C001		Yes	
Solinteq	MHS-4.2K-30	Hybrid PV inverter grid-tied	Huachuang Technology	2023/05/17	221114BWA134-EG-ZA-001	221114BWA134-EG-ZA-C001		Yes	
Solinteq	MHS-5K-30	Hybrid PV inverter grid-tied	Huachuang Technology	2023/05/17	221114BWA134-EG-ZA-001	221114BWA134-EG-ZA-C001		Yes	
Solinteq	MHS-6K-30	Hybrid PV inverter grid-tied	Huachuang Technology	2023/05/17	221114BWA134-EG-ZA-001	221114BWA134-EG-ZA-C001		Yes	
Solinteq	MHS-8K-30	Hybrid PV inverter grid-tied	Huachuang Technology	2023/05/17	221114BWA134-EG-ZA-001	221114BWA134-EG-ZA-C001		Yes	
Solinteq	MHT-10K-25	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-10K-40	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-12K-25	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-12K-40	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-15K-40	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-20K-40	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-25K-100	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	
Solinteq	MHT-30K-100	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	
Solinteq	MHT-36K-100	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	
Solinteq	MHT-40K-100	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	
Solinteq	MHT-40K-100-P	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	
Solinteq	MHT-4K-25	Hybrid PV inverter grid-tied	Huachuang Technology	2023/03/23	220422BW002-EG-ZA-001-R1	220422BW002-EG-ZA-C001-R1		Yes	
Solinteq	MHT-50K-100	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	
Solinteq	MHT-50K-100-P	Hybrid PV inverter grid-tied	Lyns-TCI Tech Guangdong	2023/08/10	230331BWA067-EG-ZA-001	230331BWA067-EG-ZA-V001		Yes	

Page 17 of 21

Solis	Solis-RHI-3.6-48ES-5G	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-3K-48ES	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-3K-48ES-5G	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-4.6K-48ES	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-4.6K-48ES-5G	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-5K-48ES	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-5K-48ES-5G	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solis	Solis-RHI-6K-48ES-5G	Hybrid PV inverter grid-tied	TÜV SÜD	2020/12/22		704092008124-00	D 0864700076 Rev 00	Yes		
Solplanet	ASW30K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW33K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW36K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW40K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW40K-LT-G2 Pro	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW45K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW45K-LT-G2 Pro	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW50K-LT-G2	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	ASW50K-LT-G2 Pro	Grid-tied PV inverter	TÜV SÜD	2022/07/25		70.409.22.286.25-00	D 099567 0067 Rev.00	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Solplanet	Solplanet ASW3000H-S2	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/07		CN22VY7J 001	AK 50550802 0001	Yes		
Solplanet	Solplanet ASW3680H-S2	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/07		CN22VY7J 001	AK 50550802 0001	Yes		
Solplanet	Solplanet ASW4000H-S2	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/07		CN22VY7J 001	AK 50550802 0001	Yes		
Solplanet	Solplanet ASW5000H-S2	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/07		CN22VY7J 001	AK 50550802 0001	Yes		
Solplanet	Solplanet ASW6000H-S2	Hybrid PV inverter grid-tied	TUV Rheinland	2022/07/07		CN22VY7J 001	AK 50550802 0001	Yes		
Soltaro	SOL-10KW-3P	Hybrid PV inverter grid-tied	TUV SÜD	2019/07/26		6429018047301A	D 104877 0003	Yes		
Sosen	SSE-HL3K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Sosen	SSE-HL3K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Sosen	SSE-HL4K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Sosen	SSE-HL4K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Sosen	SSE-HL5K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Sosen	SSE-HL6K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Sosen	SSE-HL7K-P1EU	Hybrid PV inverter grid-tied	Bureau Veritas	2024/04/29		CNQV-ESH-P24030577	U24-0317	Yes		
Specialised Battery Services (SBS)	SBS 10KHB-T	Hybrid PV inverter grid-tied	TÜV SÜD	2023/08/25		64.290.23.31113.01	D 122203 0001 Rev.00	Yes		
Specialised Battery Services (SBS)	SBS 5KHB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/19		CN23J07B 001	AK 50609817 0001	Yes		
Specialised Battery Services (SBS)	SBS 6KHB-120	Hybrid PV inverter grid-tied	TUV Rheinland	2023/12/19		CN23J07B 001	AK 50609817 0001	Yes		
Specialised Battery Services (SBS)	SBS 8KHB-T	Hybrid PV inverter grid-tied	TÜV SÜD	2023/08/25		64.290.23.31113.01	D 122203 0001 Rev.00	Yes		
SRNE	ASF48100S200-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/19		BL-DG23C0700-201	BL-DG23C0700001	Yes		
SRNE	ASF4880S190-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/19		BL-DG23C0700-201	BL-DG23C0700001	Yes		
SRNE	ASF48100S200-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/19		BL-DG23C0700-201	BL-DG23C0700001	Yes		
SRNE	ASF4880S190-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/01/19		BL-DG23C0700-201	BL-DG23C0700001	Yes		
SRNE	HESP48100S200-H	Hybrid PV inverter grid-tied	TUV NORD	2023/12/13		TRPVP06096/23E/02	COCPPV06096/23E-02	Yes		
SRNE	HESP48120S200-H	Hybrid PV inverter grid-tied	TUV NORD	2023/12/13		TRPVP06096/23E/02	COCPPV06096/23E-02	Yes		
SRNE	HESP4840S100-H	Hybrid PV inverter grid-tied	TUV NORD	2023/11/06		TRPVP06096/23E/01	COCPPV06096/23E-01	Yes		
SRNE	HESP4846S100-H	Hybrid PV inverter grid-tied	TUV NORD	2023/11/06		TRPVP06096/23E/01	COCPPV06096/23E-01	Yes		
SRNE	HESP4850S100-H	Hybrid PV inverter grid-tied	TUV NORD	2023/11/06		TRPVP06096/23E/01	COCPPV06096/23E-01	Yes		
SRNE	HESP4855S100-H	Hybrid PV inverter grid-tied	TUV NORD	2023/11/06		TRPVP06096/23E/01	COCPPV06096/23E-01	Yes		
SRNE	HESP4860S100-H	Hybrid PV inverter grid-tied	TUV NORD	2023/11/06		TRPVP06096/23E/01	COCPPV06096/23E-01	Yes		
SRNE	HESP4880S200-H	Hybrid PV inverter grid-tied	TUV NORD	2023/12/13		TRPVP06096/23E/02	COCPPV06096/23E-02	Yes		
SRNE	HYP4840S100-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/05		BL-DG23C0699-201	BL-DG23C0699001	Yes		
SRNE	HYP4850S100-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/05		BL-DG23C0699-201	BL-DG23C0699001	Yes		
SRNE	HYP4860S100-H	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/05		BL-DG23C0699-201	BL-DG23C0699001	Yes		
SRNE	SR-EOT05S-220	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/05		BL-DG23C0699-201	BL-DG23C0699001	Yes		
SRNE	SR-EOT05C-220	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/05		BL-DG23C0699-201	BL-DG23C0699001	Yes		
Sungrow	SC50HV	Battery based inverter grid-tied	TÜV SÜD	2021/08/09		704092103524-00	D 0733420345 Rev.00	Yes		
Sungrow	SC50HV-20	Battery based inverter grid-tied	TÜV SÜD	2021/08/09		704092103524-00	D 0733420345 Rev.00	Yes		
Sungrow	SG110CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19		TRSHV11090/19/02 R2	COCSHV11090/19-02 R1	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG110CX-P2	Grid-tied PV inverter	TUV Rheinland	2022/03/16		CN224TCO 001	AK 50536779 0001	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG125CX-P2	Grid-tied PV inverter	TUV Rheinland	2022/03/16		CN224TCO 001	AK 50536779 0001	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG33CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19		TRSHV11090/19/01 R2	COCSHV11090/19-01 R1	Yes		
Sungrow	SG36KTL-M	Grid-tied PV inverter	TÜV SÜD	2018/03/26		704091708604-01	D180373342197	Yes		
Sungrow	SG40CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19		TRSHV11090/19/01 R2	COCSHV11090/19-01 R1	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG50CX	Grid-tied PV inverter	TÜV NORD & Shenzhen Balun	2020/03/19		TRSHV11090/19/01 R2	COCSHV11090/19-01 R1	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG60KTL	Grid-tied PV inverter	TÜV SÜD	2018/02/08		704091708605-01	D180173342198	Yes		
Sungrow	SG75CX-P2	Grid-tied PV inverter	TUV Rheinland	2022/03/16		CN224TCO 001	AK 50536779 0001	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG80KTL	Grid-tied PV inverter	Dekra	2018/07/11		6035428.50	6035428.01AOC	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SG80KTL-20	Grid-tied PV inverter	Dekra	2018/07/11		6035428.50	6035428.01AOC	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SH10RT	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2020/07/24		TRSHV11090/19/03	COCSHV11090/19-03	Yes		
Sungrow	SH15T	Hybrid PV inverter grid-tied	SGS	2023/11/24	2028/07/04	230047RECO05-E1	230047RECO05-E1-CER	Yes		
Sungrow	SH20T	Hybrid PV inverter grid-tied	SGS	2023/11/24	2028/07/04	230047RECO05-E1	230047RECO05-E1-CER	Yes		
Sungrow	SH25T	Hybrid PV inverter grid-tied	SGS	2023/11/24	2028/07/04	230047RECO05-E1	230047RECO05-E1-CER	Yes		
Sungrow	SH3.0RS	Hybrid PV inverter grid-tied	TUV Rheinland	2022/03/15		CN22QHUH 001	AK 50536847 0001	Yes		
Sungrow	SH3.6RS	Hybrid PV inverter grid-tied	TUV Rheinland	2022/03/15		CN22QHUH 001	AK 50536847 0001	Yes		
Sungrow	SH4.0RS	Hybrid PV inverter grid-tied	TUV Rheinland	2022/03/15		CN22QHUH 001	AK 50536847 0001	Yes		
Sungrow	SH5.0RS	Hybrid PV inverter grid-tied	TUV Rheinland	2022/03/15		CN22QHUH 001	AK 50536847 0001	Yes		
Sungrow	SH5.0RT	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2020/07/24		TRSHV11090/19/03	COCSHV11090/19-03	Yes		
Sungrow	SH5K-20	Hybrid PV inverter grid-tied	Dekra	2018/05/31		6025450.51	6025450.02AOC	Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sungrow	SH6-30	Hybrid PV inverter grid-tied	Dekra	2020/03/27		6072682.50	6072682.01AOC	Yes		
Sungrow	SH6.0RS	Hybrid PV inverter grid-tied	TUV Rheinland	2022/03/15		CN22QHUH 001	AK 50536847 0001	Yes		

Sunrow	SH6.0RT	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2020/07/24	TRSHV11090/1903	COCSHV11090/19-04	Yes	
Sunrow	SH8.0RT	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2020/07/24	TRSHV11090/1903	COCSHV11090/19-04	Yes	
Sunpro	SP3K6L1	Hybrid PV inverter grid-tied	TUV SUD	2022/08/16	64.290.22.30154.01	D 107931.0034 Rev.00	Yes	
Sunpro	SP3KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/08/16	64.290.22.30154.01	D 107931.0034 Rev.00	Yes	
Sunpro	SP4K6L1	Hybrid PV inverter grid-tied	TUV SUD	2022/08/16	64.290.22.30154.01	D 107931.0034 Rev.00	Yes	
Sunpro	SP4KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/08/16	64.290.22.30154.01	D 107931.0034 Rev.00	Yes	
Sunpro	SP5KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/08/16	64.290.22.30154.01	D 107931.0034 Rev.00	Yes	
Sunpro	SP6KL1	Hybrid PV inverter grid-tied	TUV SUD	2022/08/16	64.290.22.30154.01	D 107931.0034 Rev.00	Yes	
Sunsynk	LIFE2.5HYB02	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	LIFE3.6HYB02	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	LIFE5.5HYB02	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/20	BL-DG23C0803-201	BL-DG23C0803D01	Yes	
Sunsynk	SM2.5KWLL	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	SM2.5KWLS	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	SM2.5KWPL	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	SM3.6KWLL	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	SM3.6KWLS	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	SM3.6KWPL	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/13	BL-DG2351239.201	BL-DG2351239D01	Yes	
Sunsynk	SM5.5KWGB	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/20	BL-DG23C0803-201	BL-DG23C0803D01	Yes	
Sunsynk	SM5.5KWLL	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/20	BL-DG23C0803-201	BL-DG23C0803D01	Yes	
Sunsynk	SM5.5KWLS	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/20	BL-DG23C0803-201	BL-DG23C0803D01	Yes	
Sunsynk	SM5.5KWPL	Hybrid PV inverter grid-tied	Dongguan Balun	2024/02/20	BL-DG23C0803-201	BL-DG23C0803D01	Yes	
Sunsynk	SUNSYNK-10K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	Sunsynk-10K-SG02LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/03	CN23TB9V.002	AK 50606998.0001	Yes	
Sunsynk	SUNSYNK-12K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	Sunsynk-12K-SG02LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2023/11/03	CN23TB9V.002	AK 50606998.0001	Yes	
Sunsynk	SUNSYNK-15K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	SUNSYNK-20K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	SUNSYNK-25K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	SUNSYNK-29.9K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13	CN22G75A.004	AK 50594013.0001	Yes	
Sunsynk	Sunsynk-3.6K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SUNSYNK-3.6K-SG03LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/19	BL-DG2370523-201	BL-DG2370523D01	Yes	
Sunsynk	SUNSYNK-30K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13	CN22G75A.004	AK 50594013.0001	Yes	
Sunsynk	SUNSYNK-35K-SG01HP3-EU-BM3	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13	CN22G75A.004	AK 50594013.0001	Yes	
Sunsynk	SUNSYNK-3K-SG03LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/19	BL-DG2370523-201	BL-DG2370523D01	Yes	
Sunsynk	SUNSYNK-40K-SG01HP3-EU-BM4	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13	CN22G75A.004	AK 50594013.0001	Yes	
Sunsynk	SUNSYNK-50K-SG01HP3-EU-BM4	Hybrid PV inverter grid-tied	TUV Rheinland	2023/07/13	CN22G75A.004	AK 50594013.0001	Yes	
Sunsynk	SUNSYNK-5K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	Sunsynk-5K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SUNSYNK-5K-SG03LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/19	BL-DG2370523-201	BL-DG2370523D01	Yes	
Sunsynk	SUNSYNK-6K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	Sunsynk-6K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SUNSYNK-6K-SG03LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2023/07/19	BL-DG2370523-201	BL-DG2370523D01	Yes	
Sunsynk	Sunsynk-7.6K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SUNSYNK-8K-SG01HP3-EU-AM2	Hybrid PV inverter grid-tied	TUV Rheinland	2023/02/10	CN233P2U.002	AK 50573872.0001	Yes	
Sunsynk	Sunsynk-8K-SG01LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	Sunsynk-8K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SYNK-10K-SG04LP1	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01	Yes	
Sunsynk	Synk-12K-SG01LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2022/05/31	CN222MSO.002	AK 50546025.0001	Yes	
Sunsynk	SYNK-12K-SG04LP1	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01	Yes	
Sunsynk	Synk-14K-SG01LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2022/05/31	CN222MSO.002	AK 50546025.0001	Yes	
Sunsynk	Synk-16K-SG01LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2021/09/01	CN222MSO.002	AK 50546025.0001	Yes	
Sunsynk	Synk-3.6K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	Synk-3.6K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SYNK-3.6K-SG04LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2023/01/05	CN226T63.002	AK 50570087.0001	Yes	
Sunsynk	SYNK-3K-SG04LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2023/01/05	CN22MT63.002	AK 50570087.0001	Yes	
Sunsynk	SYNK-3K-SG04LP1-24	Hybrid PV inverter grid-tied	TUV Rheinland	2023/01/05	CN22MT63.002	AK 50570087.0001	Yes	
Sunsynk	Synk-5K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	Synk-5K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SYNK-5K-SG04LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2023/01/05	CN22MT63.002	AK 50570087.0001	Yes	
Sunsynk	Synk-6K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	Synk-6K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SYNK-6K-SG04LP1	Hybrid PV inverter grid-tied	TUV Rheinland	2023/01/05	CN22MT63.002	AK 50570087.0001	Yes	
Sunsynk	SYNK-6K-SG04LP3	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01	Yes	
Sunsynk	Synk-7.6K-SG02LP1	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	Synk-7.6K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	Synk-8K-SG02LP1-B	Hybrid PV inverter grid-tied	Dongguan Balun	2022/03/30	BL-DG2220307-B01	BL-DG2220307D03	Yes	
Sunsynk	SYNK-8K-SG04LP3	Hybrid PV inverter grid-tied	TUV NORD & Shenzhen Balun	2021/06/10	BL-DG2160287-B01	BL-DG2160288D01	Yes	
Sunways	STH-3KTL-LSS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-3.6KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-4.2KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-4.6KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-5KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-6KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-7KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-8KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-10KTL-LS	Hybrid PV inverter grid-tied	Dekra	2024/08/02	6171239.50	6171239.01COC	Yes	
Sunways	STH-10KTL-HT	Hybrid PV inverter grid-tied	TUV SUD	2021/01/14	704092001222-00	D 104339.0044 Rev. 00	Yes	
Sunways	STH-12KTL-HT	Hybrid PV inverter grid-tied	TUV SUD	2021/01/14	704092001222-00	D 104339.0044 Rev. 00	Yes	
Sunways	STH-15KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-17KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-20KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-25KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-29.9KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-3.6KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08	704092101617-00	D 104339.0065 Rev.00	Yes	
Sunways	STH-3.6KTL-HSS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08	704092101617-00	D 104339.0065 Rev.00	Yes	
Sunways	STH-30KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-33KTL-HT	Hybrid PV inverter grid-tied	Dekra	2024/08/07	6193233.50	6193233.01COC	Yes	
Sunways	STH-3KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08	704092101617-00	D 104339.0065 Rev.00	Yes	
Sunways	STH-3KTL-HSS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08	704092101617-00	D 104339.0065 Rev.00	Yes	
Sunways	STH-4.2KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08	704092101617-00	D 104339.0065 Rev.00	Yes	
Sunways	STH-4.6KTL-HS	Hybrid PV inverter grid-tied	TUV SUD	2021/12/08	704092101617-00	D 104339.0065 Rev.00	Yes	
Sunways	STH-4KTL-HT	Hybrid PV inverter grid-tied	TUV SUD	2021/01/14	704092001222-00	D 104339.0044 Rev. 00	Yes	

Sunways	STH-5KTL-HS	Hybrid PV inverter grid-tied	TUV SÜD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes		
Sunways	STH-5KTL-HT	Hybrid PV inverter grid-tied	TUV SÜD	2021/01/14		704092001222-00	D 104339 0044 Rev. 00		Yes		
Sunways	STH-6KTL-HS	Hybrid PV inverter grid-tied	TUV SÜD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes		
Sunways	STH-6KTL-HT	Hybrid PV inverter grid-tied	TUV SÜD	2021/01/14		704092001222-00	D 104339 0044 Rev. 00		Yes		
Sunways	STH-7KTL-HS	Hybrid PV inverter grid-tied	TUV SÜD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes		
Sunways	STH-8KTL-HS	Hybrid PV inverter grid-tied	TUV SÜD	2021/12/08		704092101617-00	D 104339 0065 Rev.00		Yes		
Sunways	STH-8KTL-HT	Hybrid PV inverter grid-tied	TUV SÜD	2021/01/14		704092001222-00	D 104339 0044 Rev. 00		Yes		
Sunways	STT-100KTL	Grid-tied PV inverter	Dekra	2024/04/26		6193233.50	6161989.01COC		Yes		
Sunways	STT-10KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-110KTL	Grid-tied PV inverter	Dekra	2024/04/26		6193233.50	6161989.01COC		Yes		
Sunways	STT-12KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-15KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-17KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-20KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-25KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-4KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-5KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-6KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Sunways	STT-80KTL	Grid-tied PV inverter	Dekra	2024/04/26		6193233.50	6161989.01COC		Yes		
Sunways	STT-8KTL-P	Grid-tied PV inverter	TUV SÜD	2022/11/09		70.409.22.037.09-00	D 104339 0074 Rev.00		Yes		The maximum DC voltage is depended on PV array and may not exceed 1000V when this inverter is used.
Supasol	SE-H-10K 48VDC	Hybrid PV inverter grid-tied	TUV SÜD	2024/02/20		64.290.23.32286.01	D 124515 0001 Rev. 00		Yes		
Supasol	SE-H-6K 48VDC	Hybrid PV inverter grid-tied	TUV Rheinland	2024/02/28		CN24R8Y3 001	AK 50618317 0001		Yes		
Supasol	SE-H-8K 48VDC	Hybrid PV inverter grid-tied	TUV SÜD	2024/02/20		64.290.23.32286.01	D 124515 0001 Rev. 00		Yes		
Swolt	ME01-PH-SV6KW/L1	Hybrid PV inverter grid-tied	TUV SÜD	2023/08/11		64.290.23.31188.01	D 120520 0002 Rev. 00		Yes		
Swolt	ME01-PH-SV8KW/L1	Hybrid PV inverter grid-tied	TUV SÜD	2023/08/11		64.290.23.31189.01	D 120520 0002 Rev. 00		Yes		
TBB Power	Apollo Matrix 3.0M	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/03/03		TRPVP12002/21B/01	COCPPV12002/21B-01		Yes		
TBB Power	Apollo Matrix 3.0S	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/03/03		TRPVP12002/21B/01	COCPPV12002/21B-01		Yes		
TBB Power	Apollo Matrix 5.0S	Hybrid PV inverter grid-tied	TUV NORD (Hangzhou)	2022/03/03		TRPVP12002/21B/01	COCPPV12002/21B-01		Yes		
TBB Power	Qoma 33H	Battery based inverter grid-tied	TUV NORD (Hangzhou)	2023/09/18		TRPVP05005/22E/01 R1	COCPPV05005/22E-01 R1		Yes		
TBB Power	Qoma 33H-R	Battery based inverter grid-tied	TUV NORD (Hangzhou)	2023/09/18		TRPVP05005/22E/01 R1	COCPPV05005/22E-01 R1		Yes		
TBB Power	RiO 2KVA-M	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO 2KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO 3KVA-M	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO 3KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO 4KVA-M	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO 5KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO 6KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO II 2KVA-M	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 2KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 3KVA-M	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 3KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 4KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 5KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 6KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO II 8KVA-S	Battery based inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun 2KVA-M	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun 2KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun 3KVA-M	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun 3KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun 4KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun 5KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun 6KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/16		TRPVP12006/23E/03	COCPPV12006/23E-02		Yes		
TBB Power	RiO Sun II 2KVA-M	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 2KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 3KVA-M	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 3KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 4KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 5KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 6KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	RiO Sun II 8KVA-S	Hybrid PV inverter grid-tied	TUV NORD	2024/01/22		TRPVP12006/23E/04	COCPPV12006/23E-01		Yes		
TBB Power	Tyrann 10.0S	Battery based inverter grid-tied	TUV NORD	2024/04/22		TRPVP03055/24E/01	COCPPV03055/24E-01		Yes		
TBB Power	Tyrann 15.0S	Battery based inverter grid-tied	TUV NORD	2024/04/22		TRPVP03055/24E/01	COCPPV03055/24E-01		Yes		
TBB Power	Tyrann 8.0S	Battery based inverter grid-tied	TUV NORD	2024/04/22		TRPVP03055/24E/01	COCPPV03055/24E-01		Yes		
TELE Haase Steuergerate	NA003	Network & system relay	Primara	2018/09/20		14PP035-12	18-315-00		Yes		Network and system grid protection voltage and frequency relay only and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list
Tesla	AC Powerwall 1092170-xx-y	Battery based inverter grid-tied	Intertek	2020/05/20		102581059CRT-051c	102581059CRT-051c		Yes		
Tesla	AC Powerwall 202170-xx-y	Battery based inverter grid-tied	Intertek	2020/05/20		102581059CRT-051c	102581059CRT-051c		Yes		
UCanPower	UHC-8KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-10KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-10KT-40	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-12KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-12KT-40	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-15KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-20KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-4KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-5KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
UCanPower	UHC-6KT	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/03/24		HC23112802002-EG-ZA-001	HC23112802002-EG-ZA-V001		Yes		
Unipassion	UP-1P10K-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/09/20		64.290.23.31500.01	D 122606 0001 Rev.00		Yes		
Unipassion	UP-1P2K-60	Hybrid PV inverter grid-tied	TUV Rheinland Group	2023/09/15		CN231YHP 001	AK 50602123 0001		Yes		
Unipassion	UP-1P5K-HI	Hybrid PV inverter grid-tied	TUV Rheinland Group	2023/09/15		CN231YHP 001	AK 50602123 0001		Yes		
Unipassion	UP-1P6K-60	Hybrid PV inverter grid-tied	TUV Rheinland Group	2023/09/15		CN231YHP 001	AK 50602123 0001		Yes		
Unipassion	UP-1P6K-HI	Hybrid PV inverter grid-tied	TUV Rheinland Group	2023/09/15		CN231YHP 001	AK 50602123 0001		Yes		
Unipassion	UP-1P8K-HI	Hybrid PV inverter grid-tied	TUV SÜD	2023/09/20		64.290.23.31500.01	D 122606 0001 Rev.00		Yes		
Veichi	VHT-25K-100-H	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		
Veichi	VHT-30K-100-H	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		
Veichi	VHT-36K-100-H	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		
Veichi	VHT-40K-100-H	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		

Veichi	VHT-40K-100-HP	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		
Veichi	VHT-50K-100-H	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		
Veichi	VHT-50K-100-HP	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2024/07/05		HC24041801001-EG-ZA-001	HC24041801001-EG-ZA-V001		Yes		
Victron	MultiGrid - II 48/3000/35-32	Battery based inverter grid-tied	Primara	2018/10/02		17PP264-07_1	18-320-00	Yes			
Victron	MultiGrid 12/3000/120-50	Battery based inverter grid-tied	Primara	2017/11/20		16PP183-06_1	17-303-00	Yes			
Victron	MultiGrid 24/3000/70-50	Battery based inverter grid-tied	Primara	2017/11/20		16PP183-06_1	17-303-00	Yes			
Victron	MultiGrid 48/3000/35-50	Battery based inverter grid-tied	Primara	2017/11/20		16PP183-06_1	17-303-00	Yes			
Victron	MultiPlus - II 48/3000/35-32	Battery based inverter grid-tied	Kiwa Primara	2019/08/22		17PP264-07_3	18-320-01	Yes			
Victron	MultiPlus - II 48/3000/35-32GX	Battery based inverter grid-tied	Kiwa Primara	2019/08/22		17PP264-07_3	18-320-01	Yes			
Victron	MultiPlus - II 48/5000/70-50	Battery based inverter grid-tied	Kiwa Primara	2019/08/22		17PP264-07_3	18-320-01	Yes			
Victron	MultiPlus-II 48/10000/140-100	Battery based inverter grid-tied	SGS	2023/09/29	2028/08/29	2222 / 0478 - G-E1	2622/0478-G-E1-CER		Yes		
Victron	MultiPlus-II 48/15000/200-100	Battery based inverter grid-tied	SGS	2023/09/29	2028/08/29	2222 / 0478 - G-E1	2622/0478-G-E1-CER		Yes		
Victron	MultiPlus-II 48/8000/110-100	Battery based inverter grid-tied	SGS	2023/09/29	2028/08/29	2222 / 0478 - G-E1	2622/0478-G-E1-CER		Yes		
Victron	Quattro 48/15000/200-100/100	Battery based inverter grid-tied	SGS	2023/11/12	2028/10/26	2220 / 0019 - L -E1	2620/0019-L-E1-CER		Yes		
Volltronic	InfiniSolar 10k	Hybrid PV inverter grid-tied	Bureau Veritas	2020/10/30		PVZA180904N057-R1	2088AP0923N001001	Yes			
Volltronic	MAX DUPLEX S 10K	Hybrid PV inverter grid-tied	Intertek	2023/10/18	2028/10/17	230900166SHA-001	23SHD1064-01		Yes		
Volltronic	MAX DUPLEX S 11K	Hybrid PV inverter grid-tied	Intertek	2023/10/18	2028/10/17	230900166SHA-001	23SHD1064-01		Yes		
Watsonic	3.6K-30A-1P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/11/13		HC23072004002-EG-ZA-001	HC23072004002-EG-ZA-V001		Yes		
Watsonic	10.0K-25A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	10.0K-40A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	12.0K-25A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	12.0K-40A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	15.0K-40A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	20.0K-40A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	3.0K-30A-1P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/11/13		HC23072004002-EG-ZA-001	HC23072004002-EG-ZA-V001		Yes		
Watsonic	4.0K-25A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	4.2K-30A-1P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/11/13		HC23072004002-EG-ZA-001	HC23072004002-EG-ZA-V001		Yes		
Watsonic	5.0K-25A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	5.0K-30A-1P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/11/13		HC23072004002-EG-ZA-001	HC23072004002-EG-ZA-V001		Yes		
Watsonic	6.0K-25A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	6.0K-30A-1P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/11/13		HC23072004002-EG-ZA-001	HC23072004002-EG-ZA-V001		Yes		
Watsonic	8.0K-25A-3P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/10/10		HC23072004003-EG-ZA-001	HC23072004003-EG-ZA-V001		Yes		
Watsonic	8.0K-30A-1P	Hybrid PV inverter grid-tied	Lyns-TCl Tech Guangdong	2023/11/13		HC23072004002-EG-ZA-001	HC23072004002-EG-ZA-V001		Yes		
Ziehl	UFR1001E relay	Network & system relay	Bureau Veritas	2018/06/07		11TH0501-NRS 097-2-1_1	U18-0308	Yes			Network and system grid protection voltage and frequency relay only and may only be used in conjunction with approved NRS 097-2-1 type tested inverters on this list
Zola	Edge Inverter 81005-00001	Grid-tied PV inverter	Bureau Veritas	2024/03/28		PVZA2401WDG0035-1	U24-0220		Yes		

RCMU - residual current monitoring unit
RCD - residual current device
RCM - residual current monitoring
SPD - surge protection device