

ELECTRICITY SERVICES

MBM/COMM

SSEG INSTALLATION COMMISSIONING REPORT

Page 1

The following SSEG Commissioning Report must be submitted for each installation, confirming compliance with the Municipality's requirements.

Site Details				
Property address (incl. post code)				
Contract account number				
Contact Details				
SSEG property owner				
Contact person				
Contact telephone number				
SSEG Details				
Manufacturer				
Туре				
Model				
Serial number/s of inverter/s and independent				
disconnection switching unit/s (if not integrated				
into one of the components of the embedded				
generator)				
Serial number / version numbers of software				
(where appropriate)				
SSEG rating (kVA) and power factor (under				
normal running conditions)				
Single or three phase				
Maximum peak AC short circuit current (A)				
Type of prime mover (e.g. inverter or rotating				
machine) and fuel source (e.g. sun, biomass,				
wind)				
Location of SSEG within the installation				



ELECTRICITY SERVICES

MBM/COMM

SSEG INSTALLATION COMMISSIONING REPORT

Page 2

	Installer Details			
Installer				
A 111 (1 / 116)				
Accreditation/qualification				
Address (incl. post code)				
, , ,				
Contact person				
Contact person				
Telephone number				
Fax number				
E-mail address				
L-IIIaii addiess				
Information to be enclosed				
Final copy of circuit diagram				
Inverter type test Certificate of Compliance and Test Report according to NRS 097-2-1,				
issued by accredited 3rd party test house (not necessary if already provided).				
Factory setting sheet or other documentation showing that the inverter has been set				
according to NRS 097-2-1 An electrical installation Certificate of Compliance.				
An electrical installation certificate	or compliance.			
Signed contract for SSEG				
Operation and maintenance proce	dure			



ELECTRICITY SERVICES

MBM/COMM

SSEG INSTALLATION COMMISSIONING REPORT

Page 3

Compulsory declaration – to be completed by ECSA registered Pr. Eng. or Pr. Tech Eng.					
The SSEG installation complies with the relevan	nt sections of NRS	097-2-1.			
The loss of mains protection has been proved b	y a functional test	carried out as part of the on-site			
commissioning, e.g. a momentary disconnection	commissioning, e.g. a momentary disconnection of the supply to the SSEG in order to prove that				
the loss of mains protection operates as expecte	ed.				
Protection settings have been set to comply with	n NRS 097-2-1				
Safety labels have been fitted in accordance wit	h NRS 097-2-1				
The SSEG installation complies with the relevan	nt sections of SAN	S 10142-1 and an installation			
certificate of compliance is attached.					
Reverse power blocking protection system insta	Illed and commiss	ioned to prevent reverse power			
flow onto the distribution electricity network (where applicable)					
Comments (continue on separate sheet if neces	ssary)				
Name:	Signature:	Date:			
ECSA Prof.	Reg. No.:				
Category:					